

Scilab Textbook Companion for
Generation Of Electrical Energy
by B. R. Gupta¹

Created by
Anil Kumar Kesavarapu
B.Tech
Electrical Engineering
VISVESVARAYA NATIONAL INSTITUTE OF TECHNOLOGY
College Teacher
V.S.kale
Cross-Checked by

July 31, 2019

¹Funded by a grant from the National Mission on Education through ICT, <http://spoken-tutorial.org/NMEICT-Intro>. This Textbook Companion and Scilab codes written in it can be downloaded from the "Textbook Companion Project" section at the website <http://scilab.in>

Book Description

Title: Generation Of Electrical Energy

Author: B. R. Gupta

Publisher: S. Chand Publishing, New Delhi

Edition: 14

Year: 2011

ISBN: 81-219-0102-2

Scilab numbering policy used in this document and the relation to the above book.

Exa Example (Solved example)

Eqn Equation (Particular equation of the above book)

AP Appendix to Example(Scilab Code that is an Appednix to a particular Example of the above book)

For example, Exa 3.51 means solved example 3.51 of this book. Sec 2.3 means a scilab code whose theory is explained in Section 2.3 of the book.

Contents

List of Scilab Codes	4
2 LOADS AND LOAD CURVES	6
3 power plant economics	27
4 TARIFFS AND POWER FACTOR IMPROVEMENT	37
5 SELECTION OF PLANT	58
7 THERMAL POWER PLANTS	67
8 hydro electric plants	68
9 Nuclear Power stations	79
10 ECONOMIC OPERATION OF STEAM PLANTS	84
11 HYDRO THERMAL CO ORDINATION	100
12 parallel operation of alternators	107
13 MAJOR ELECTRICAL EQUIPMENT IN POWER PLANTS	113
14 SYSTEM INTERCONNECTIONS	123

15 NEW ENERGY SOURCES	140
17 GENERATING CAPACITY RELIABILITY EVALUTION	149
20 ENERGY AUDIT	157
23 CAPTIVE POWER GENERATION	161

List of Scilab Codes

Exa 2.1	connected load demand factor and other load factors connected to the system	6
Exa 2.2	diversity factor concerning different loads . .	7
Exa 2.3	load demand power from load	10
Exa 2.4	load deviation curve and load factor	11
Exa 2.5	capacity factor and utilisation factor	13
Exa 2.6	mass curve of 24 example	14
Exa 2.7	annual production of plant with factors . . .	16
Exa 2.8	daily load factor	17
Exa 2.9	load duration curve and mass curve	18
Exa 2.10	reserve capacity of plant with different factors	20
Exa 2.11	suggested installed capacity for a plant . . .	21
Exa 2.12	load duration curve	23
Exa 2.13	annual load factor daily load factor and different ratios	24
Exa 2.14	peak load on different transformers and peak load on feeder	25
Exa 3.1	annual plant cost and generation cost of two different units	27
Exa 3.2	annual depreciation reserve	28
Exa 3.3	solving accumulated depreciation	29
Exa 3.4	load factor verses generation cost	29
Exa 3.5	generation cost of per unit of energy	31
Exa 3.6	comparision between costs of different alternators	32
Exa 3.7	overall generation cost per kWh for thermal and hydro plant	33
Exa 3.16	generation cost of a plant	34

Exa 3.17	to find the generation cost and total annual cost	35
Exa 4.1	monthly electricity consumption	37
Exa 4.2	total electricity bill per year	38
Exa 4.3	annual cost operating cost tariff	38
Exa 4.4	monthly bill and average tariff per kWh	40
Exa 4.5	better consumption per year	41
Exa 4.6	average energy cost in different case	41
Exa 4.7	selection of cheaper transformer	42
Exa 4.8	most economical power factor and rating of capacitor bank	44
Exa 4.9	maximum load at unity power factor which can be supplied by this substation	44
Exa 4.10	kvar rating of star connected capacitor and capacitance for power factor	45
Exa 4.11	kva and power factor of synchronous motor	46
Exa 4.12	parallel operation of synchronous and induction motor under different	47
Exa 4.13	finding power factor and load on different generator	48
Exa 4.14	loss if capacitor is connected in star and delta	49
Exa 4.15	percentage reduction in line loss with the connection of capacitors	51
Exa 4.16	kva of capacitor bank and transformer and etc	51
Exa 4.17	MVA rating of three winding of transformer	53
Exa 4.18	load power and power factor of 3 ph alternator	53
Exa 4.19	maintaining of power factor using capacitor	54
Exa 4.20	maintaining of power factor using capacitor	55
Exa 4.21	difference in annual fixed charges of consumer for change in pf	55
Exa 4.22	finding annual cost and difference in annual cost in two units	56
Exa 5.1	selection of plant on criteria of investment other	58
Exa 5.2	selection of plant on criteria of investment with out interest and depreciation	60
Exa 5.3	calculate the capital cost	62
Exa 5.4	rate of return method for best plan	63

Exa 7.1	calculation of energy input to the thermal plant and output from thermal plant	67
Exa 8.1	hydro plant power with parameters of reservoir	68
Exa 8.2	STORAGE CAPACITY AND HYDRO GRAPH	68
Exa 8.3	STORAGE CAPACITY AND HYDRO GRAPH	70
Exa 8.4	derevation of mass curve	73
Exa 8.5	HYDRO GRAPH	76
Exa 8.6	WATER USED AND LOAD FACTOR OF HYDRO STATION	77
Exa 9.1	energy equivalent of matter 1 gram	79
Exa 9.2	mass defect of 1 amu	79
Exa 9.3	binding energy of $1\text{h}2\ 28\text{ni}59\ 92\text{u}235$	80
Exa 9.4	half life of uranium	81
Exa 9.5	power produced by fissioning 5 grams of uranium	81
Exa 9.6	fuel requirement for given energy	82
Exa 9.7	number of collisions for energy change	82
Exa 10.1	SHARING OF LOAD BETWEEN STATIONS	84
Exa 10.2	COST ON DIFFERENT STATIONS ON INCREMENTAL COST METHOD	86
Exa 10.3	SHARING OF LOAD BETWEEN STATIONS WITH PARTICIPATION FACTOR	87
Exa 10.5	LOSS COEFFICIENTS AND TRANSMISSION LOSS	88
Exa 10.7	LOSS COEFFICIENTS AND TRANSMISSION LOSS	89
Exa 10.8	SHARING OF LOAD BETWEEN STATIONS WITH PARTICIPATION FACTOR	90
Exa 10.9	COST CONDITIONS WITH CHANGE IN LOAD ON PLANT	91
Exa 10.10	SHARING OF LOAD BETWEEN STATIONS WITH ITERATION METHOD	92
Exa 10.11	COST CHARACTERISTIC UNDER COMBAINED STATIONS CONDITION	92
Exa 10.12	SHARING OF LOAD BETWEEN STATIONS	93
Exa 10.13	ECONOMIC SCHEDULING BETWEEN POWER STATION	94

Exa 10.14	ECONOMIC SCHEDULING BETWEEN POWER STATION	95
Exa 10.15	ECONOMIC SCHEDULING BETWEEN POWER STATION	96
Exa 10.16	COMPARITION BETWEEN UNIFORM LOAD AND DISTRUBTED LOAD	97
Exa 10.17	ECONOMIC SCHEDULING BETWEEN POWER STATION	98
Exa 11.1	SCHEDULING OF POWER PLANT	100
Exa 11.2	generation schedule and daily water usage of power plant	104
Exa 11.3	water usage and cost of water by hydro power plant	106
Exa 12.1	load sharing between alternators	107
Exa 12.2	different parameters between parallel operation of generator	108
Exa 12.3	circulating current between parallel generators	109
Exa 12.4	different parameters between parallel operation of generator	109
Exa 12.5	synchronising power per mechanical degree of angular displacement	110
Exa 12.6	synchronising power per mechanical degree of angular displacement	111
Exa 12.7	load parameters between alternators	111
Exa 13.1	fault current with different generators	113
Exa 13.2	short circuit current parallel generator	114
Exa 13.3	short circuit MVA	115
Exa 13.4	fault MVA in parallel generators	116
Exa 13.5	REATING OF CIRCUIT BREAKER	116
Exa 13.6	ratio of mech stresses on short circuit to mech stresses on full load	118
Exa 13.7	percentage drop in bus bar voltage	119
Exa 13.8	short circuit MVA on hv and lv side	119
Exa 13.9	limiting the MVA with reactance	120
Exa 13.10	fault current with different circuit	120
Exa 13.11	fault level and fault MVA	121
Exa 14.1	speed regulation and frequency drop in alternator	123

Exa 14.2	frequency deviation in alternator	123
Exa 14.3	speed regulation in sharing alternator	124
Exa 14.4	static frequency drop for change in load	125
Exa 14.5	primary ALFC loop paramers	125
Exa 14.6	frequency drop and increased generation to meet the increase in load	126
Exa 14.7	frequency deviation before the value opens to meet the load demand	127
Exa 14.8	largest change in step load for constant dura- tion of frequency	127
Exa 14.9	frequency responce and static frequency error in the absence of secondary loop	128
Exa 14.10	change in frequency in transfer function	129
Exa 14.11	stactic frequency drop and change in power line with parameters	130
Exa 14.12	change in frequency and change power in dif- ferent area	131
Exa 14.13	steady state change in tie line power if step change in power	132
Exa 14.14	capacitance of shunt load capacitor to main- tain voltage constant	133
Exa 14.15	maintaining voltage costant by tapping trans- former	134
Exa 14.16	output voltage with reactive power	135
Exa 14.17	generation at each station and transfer of power of different plants	136
Exa 14.18	current transfer between two station	137
Exa 14.19	current in interconnector with different power factor	138
Exa 15.1	open circuit voltage internal resistance maxi- mumpower in MHD engine	140
Exa 15.2	open circuit voltage gradiant in duct due to load in MHD engine	140
Exa 15.3	losses in duct power delivered to load effi- ciency current density in duct in MHD gen- erator	141
Exa 15.4	output voltage maximum power output in MHD generator	142

Exa 15.5	power collected by surface of collector and temperature rise in photo generators	143
Exa 15.6	peak watt capacity of PV panel and number of modules of photo voltaic cell	144
Exa 15.7	power available power density torque at maximum power of wind mills	145
Exa 15.8	difference pressure in pascals and other unit of wind mill	145
Exa 15.9	output surface area of reservoir in tidal power plant	146
Exa 15.10	comparison between tidel and coal plant . .	147
Exa 17.1	CAPACITY OUTAGE PROBABILITY TABLE	149
Exa 17.2	CAPACITY OUTAGE PROBABILITY TABLE AND CUMMULATIVE PROBABILITY	150
Exa 17.3	CAPACITY OUTAGE PROBABILITY TABLE AND CUMMULATIVE PROBABILITY	151
Exa 17.4	CAPACITY OUTAGE PROBABILITY TABLE- AND EXPECTED LOAD	153
Exa 20.1	economic power factor electricity bill	157
Exa 20.2	annual cost method present worth method .	158
Exa 23.1	COST OF DIESEL ENGINE CAPITIVE POWER PLANT	161
Exa 23.2	GENERATION COST OF CAPITIVE POWER PLANT in suger mill	162
Exa 23.11.2	calculation of wheeling charges	163

List of Figures

2.1	diversity factor concerning different loads	8
2.2	load deviation curve and load factor	12
2.3	mass curve of 24 example	14
2.4	daily load factor	17
2.5	load duration curve and mass curve	19
2.6	load duration curve	22
3.1	load factor verses generation cost	30
8.1	STORAGE CAPACITY AND HYDRO GRAPH	69
8.2	STORAGE CAPACITY AND HYDRO GRAPH	71
8.3	derevation of mass curve	73
8.4	HYDRO GRAPH	75
11.1	SCHEDULING OF POWER PLANT	101
17.1	CAPACITY OUTAGE PROBABILITY TABLE AND CUM- MULATIVE PROBABILITY	152
17.2	CAPACITY OUTAGE PROBABILITY TABLEAND EXPECTED LOAD	154

Chapter 2

LOADS AND LOAD CURVES

Scilab code Exa 2.1 connected load demand factor and other load factors connected

```
1 clc
2 disp("example =2.1")
3 printf("\n")
4 disp("solution for (a)")
5 nb=8;nf=2;n1=2 //given number of equipments is 8
   bulbs 2 fans 2plugs
6 lb=100;lf=60;l1=100 //corresponding wattages
7 cl=nb*lb+nf*lf+n1*l1; //total connected load
8 printf("connected load = 8X100W+2X60W+2X100W=%dW\n",
   cl);
9 disp("solution for (b)")
10 disp("total wattage at different times is")
11 t1=5;t2=2;t3=2;t4=9;t5=6;
12 fr=[0 1 0] //12 to 5am period of duration 5h
13 s=[0 2 1] //5am to 7am period of duration 2h
14 t=[0 0 0] //7am to 9am period of duration 2h
15 fo=[0 2 0] //9am to 6pm period of duration 9h
16 fi=[4 2 0] //6pm to 12pm period of duration 6h
17 w=[fr;s;t;fo;fi]
18 wt=[100*w(:,1),60*w(:,2),100*w(:,3)]
19 wtt=[sum(wt(1,:));sum(wt(2,:));sum(wt(3,:));sum(wt
```

```

    (4,:));sum(wt(5,:))
20 printf("\t%dW\n\t%dW\n\t%dW\n\t%dW\n\t%dW",wtt(1),
    wtt(2),wtt(3),wtt(4),wtt(5))
21 disp("\nthe maximum demand is %dW\n",max(wtt))
22 m=max(wtt)
23 disp("solution for (c)")
24 printf("\ndemand factor =%3f\n",m/c1)
25 disp("solution for (d)")//energy consumed is power
    multiply by corresponding time
26 energy=[wtt(1,1)*t1;wtt(2,1)*t2;wtt(3,1)*t3;wtt(4,1)
    *t4;wtt(5,1)*t5]
27 printf("\t%dWh\n\t%dWh\n\t%dWh\n\t%dWh\n\t%dWh",
    energy(1),energy(2),energy(3),energy(4),energy(5)
    )
28 e=sum(energy)
29 printf("\ntotal energy consumed during 24 hours =
    %dWh+%dWh+%dWh+%dWh+%dWh=%dWh\n",energy(1),energy
    (2),energy(3),energy(4),energy(5),e)
30 disp("solution for (e)");
31 ec=c1*24;
32 printf("\nif all devices are used throughout the day
    the energy consumed in Wh is %dWh \n\t\t%.2fkWh"
    ,ec,ec/1000)
33 //for 24 hours of max. load

```

Scilab code Exa 2.2 diversity factor concerning different loads

```

1 clc
2 disp("example 2.2")
3 disp("(a)");
4 mca=1.1;c1a=2.5;mcb=1;c1b=3;           //mca=maximum

```




Figure 2.1: diversity factor concerning different loads

```

demand of consumera;cla=connected load of a;mcb=
maximum load of consumer b;clb=connected load of
consumer b
5 printf("maximum demand of consumer A =%1fkW \n \
ndemand factor of consumer A =%2f \n \nmaximum
demand of consumer B =%dkW\n \ndemand factor of
consumer B = %2f",mca,mca/cla,mcb,mcb/clb)
6 disp("(b)")
7 printf("The variation in demand versus time curves
are plotted and shown in Fig This is known as
chonological load curve.")
8 A=[100*ones(1,5),1100*ones(1,1),200*ones(1,2),0*ones
(1,9),500*ones(1,7)]
9 B=[0*ones(1,7),300*ones(1,1),1000*ones(1,2),200*ones
(1,8),600*ones(1,5),0*ones(1,1)]; //time line of
different periods by a and b consumers
10 t=1:1:24 ;//for 24 hours plotting
11 ma=max(A);mb=max(B);
12 subplot(121); //matrix plotting
13 plot2d2(t,A,1);
14 plot2d2(t,B,2);
15 xtitle("load curves of A and B/ fig 1","time","load
watts")
16 C=A+B;
17 subplot(122);
18 plot2d2(t,C,1);
19 xtitle("chronological load of group / fig 2","time",
"load watts")
20 mg=max(C); //maximum demand of group
21 disp("(c)")
22 printf("maximum demand of the group is %dW",mg);
23 gd=(ma+mb)/mg;
24 printf("group diversity factor = %3f",gd) ; //group
diversity factor is sum of individual maximum
consumauer load to the group max load
25 disp("(d)")
26 sa=sum(A)
27 printf("energy consumed by A during 24 hours is =

```



```

    %dWh",sa)
28 printf("\nit is seen that energy consumed by A is
    equal to the area under the chronological load
    curve of A \n energy consumed by B during 24
    hours is")
29 sb=sum(B);
30 printf("300x1+100x2+200x8+600x5=%dWh",sb);
31 disp("(e)");
32 printf("maximum energy which A could consume in 24
    hours = %.2fkWh \nmaximum energy which B consume
    in 24 hours is =%.2fkWh",mca*24,mcb*24 );
33 disp("(f)");
34 printf("actual energy/maximum energy");
35 mca=mca*10^3;mcb=mcb*10^3
36 aemea=sa/(mca*24)
37 aemeb=sb/(mcb*24)
38 printf("\nfor A = %d/%d =%f \nfor b =%d/%d =%f",sa,
    mca*24,sa/(mca*24),sb,mcb*24,aemeb);

```

Scilab code Exa 2.3 load demand power from load

```

1 clc
2 disp("example 2.3")
3 printf("\n")
4 cola=5;na=600;ns=20;
5 cls=2;clfm=10;clsm=5;cll=20;clci=80;
6 dffl=0.7;dfsm=0.8;dffl=0.65;dfci=0.5;
7 nsl=200;cls1=0.04;dfa=0.5;gdfa=3.0;
8 pdfa=1.25;gdfc=2;pdfc=1.6;dfs=0.8; //given col||cl=
    connected load,n=number,df=demand factor,gdf=
    group diversity factor,pdf=peak diversity factor,
    a=appartement,c=commercia,shop,sl=streetlight,
    fm=flourmill,sm=saw mill,l=laundry,ci=cinema

```

```

    complex.
9  mdea=cola*dfa
10 printf("maximum demand of each apartment =%.2fkWh \
    n",mdea)
11 mda=(na*mdea)/gdfa
12 printf("maximum demand of 600 apatments =%.2fkW \n",
    mda);
13 datsp=mda/pdfa
14 printf("demand of 600 apartments at time of the
    system peak =%dkW \n",datsp);
15 mdtcc=((cls*ns*dfs)+(clfm*dffl)+(clsm*dfsm)+(cll*dfl
    )+(clci*dfci))/gdfc
16 printf("maximum demand of total commertial complex=
    %dkW \n",mdtcc)
17 dcsp=mdtcc/pdfc
18 printf("demand of the commertial load at the time of
    the peak = %dkW\n",dcsp);
19 dsltsp=ns1*cls1
20 printf("demand of the street lighting at the time of
    the system peak =%dkW",dsltsp);
21 ispd=datasp+dcsp+dsltsp
22 printf("\nincrease in system peak deamand =%dkW ",
    ispd)

```

Scilab code Exa 2.4 load deviation curve and load factor

```

1  clc
2  disp("example 2.4")
3  printf("\n")
4  printf("the chronological load curve is plotted in
    fig 1 the durition of loads is as under :")

```




Figure 2.2: load deviation curve and load factor

```

5  lc=[20*ones(1,5),40*ones(1,4),80*ones(1,9),100*ones
      (1,4),20*ones(1,2)]
6  ldc=gsort(ldc);
7  [mm,nn]=size(ldc)
8  printf("\n")
9  for i=1:nn
10 printf("\t%dW",ldc(i));//arranging accending order
11 end
12 e=sum(ldc)
13 printf("\nthe load duration curve is plotted in 2 the
          energy produced by plant in 24 hours \n =100x4
          +80x(13-4)+40(17-13)+20(24-17)=%dMWh \n",e);
14 lff=e/(24*max(ldc));
15 printf("load factor =1420/2400=%f=%f in persent",lff
          ,lff*100)
16 t=1:1:24
17 subplot(121);
18 plot2d2(t,lc);
19 xtitle("chronological curve","time","load MW");
20 subplot(122);
21 plot2d2(t,ldc);
22 xtitle("load duration curve","time","load MW");

```

Scilab code Exa 2.5 capacity factor and utilisation factor

```

1  clc
2  disp("example 2.5")
3  lf=0.5917;ml=100;ic=125; //lf=load factor,ic=
      installed capacity,ml=maximum load,cf=capacity
      factor,uf=utilization factor
4  cf=(ml*lf)/ic;uf=ml/lf

```




Figure 2.3: mass curve of 24 example

```
5 printf("capacity factor =%f",cf)
6 printf("\nutilisation factor =%f",uf)
```

Scilab code Exa 2.6 mass curve of 24 example

```
1 clc
2 disp("Example 2.6")
3 time=[5 9 18 22 24]
4 loadt=[20 40 80 100 20] //given
   time and load
5 k=size(time)
```

```

6 k=k(1,2)
7 timed(1,1)=time(1,1)
8 for x=2:k //
    finding time duration of each load
9     timed(1,x)=time(1,x)-time(1,x-1)
10 end
11 [m n]=gsort(loadt) //sorting
    decreasing order
12 for x=1:k //sorting
    the load and timeduration correspondingly
13     timed1(1,x)=timed(1,n(x))
14 end
15 tim(1,1)=timed1(1,1)
16 for x=2:k
17     tim(1,x)=timed1(1,x)+tim(1,x-1)
18 end
19 lo(1,1)=24*min(m)
20 m(k+1)=[]
21 printf("the energy at different load levels is as
    under :")
22 printf("\nload=%dMW, energy=%dMWh",m(k),lo(1,1))
23 y=2
24 for x=k-2:-1:1
25     lo(1,y)=lo(1,y-1)+(tim(1,x))*(m(x)-m(x+1))
26     t=m(x);l=lo(1,y)
27     printf("\nload=%dMW, energy=%dMWh",t,l)
28     y=y+1
29 end
30 for x=1:k
31     for y=x+1:k
32         if m(1,x)==m(1,y) then
33             m(1,y)=[]
34         end
35     end
36 end
37 pop=gsort(m,'g','i')
38 subplot(121)
39 plot(lo,pop)

```

```

40 xtitle("energy load curve","energy","load")
41 //time=[5 9 18 22 24]
42 //loadt=[20 40 80 100 20]
43 printf("\\nthe energy load curve is plotted in fig 1
    \\nthe energy supplied up to different times of
    the day is as under :")
44 et(1,1)=time(1,1)*loadt(1,1)
45 for x=2:k
46     printf("\\nenergy supplied upto %d is %dMWh",time
        (1,x-1),et(1,x-1))
47     et(1,x)=et(1,x-1)+loadt(1,x)*(time(1,x)-time(1,x
        -1))
48
49 end
50 subplot(122)
51 plot(time,et)
52 xtitle("masscurve","time in hours","load in MW")

```

Scilab code Exa 2.7 annual production of plant with factors

```

1 clc
2 disp("example 2.7")
3 md=40;cf=0.5;uf=0.8; //maximum demand in MW; capacity
    factor; utility factor
4 disp("(a)")
5 lf=cf/uf; //load factor is ratio of capacity factor
    to the utility factor
6 printf("load factor = capacity factor/utilisation
    factor =%f",lf)
7 disp("(b)")
8 pc=md/uf; //plant capacity is ratio of maximum
    demand to utility factor
9 printf("plant capacity = maximum demand/utilisation

```




Figure 2.4: daily load factor

```

    factor =%dMW" ,pc)
10 disp(" c")
11 rc=pc-md; //reserve capacity is plant capacity
    minus maximum demand
12 printf("reserve capacity =%dMW" ,rc)
13 disp(" d")
14 printf("annual energy production =%dMWh" ,md*lf*8760)

```

Scilab code Exa 2.8 daily load factor


```

1  clc
2  disp("example 2.8")
3  disp("the chronological load curve is plotted in fig
      1")
4  a=[0 5 9 18 20 22 24] //time in matrix format
5  b=[50 50 100 100 150 80 50] //load in matrix format
6  for x=1:6
7      z(1,x)=((b(1,x)+b(1,x+1))/2)*(a(1,(x+1))-a(1,x))
8  end
9  e=sum(z);
10 printf("energy required required by the system in 24
      hrs \n =50x5MWh+((100+50)/2)x4MWh +(100x9)MWh
      +(100+150)MWh+(150+80)MWh+(80+50)MWh \n =%dMWh",
      sum(z))
11 dlf=e/(max(b)*24)
12 printf("\ndaily load factor =2060/(150x24) =%f",dlf)
13 plot(a,b)
14 xtitle("load curve", "time", "MW")

```

Scilab code Exa 2.9 load duration curve and mass curve

```

1  clc
2  clear
3  disp("example 2.9")
4  disp("load duration curve in fig1")
5  disp("the energy consumed upto different times is as
      ")
6  a=[0 5 9 18 20 22 24] //time in matrix format
7  b=[50 50 100 100 150 80 50] //load in matrix format
8  for x=1:6
9      z(1,x)=((b(1,x)+b(1,x+1))/2)*(a(1,(x+1))-a(1,x))

```




Figure 2.5: load duration curve and mass curve

```

10 end
11 et=0
12 for x=1:6
13     et=et+z(1,x);
14     A=a(1,(x+1))
15     ett(1,x)=et;
16     q(1,x)=a(1,x+1)
17     printf("\nfrom mid night upto %d,energy=%dMWh",A
            ,et)
18 end
19 q(1,x+1)=[]
20 [m n]=gsort(b)
21 m(1,7)=[];m(1,6)=[]; //rearranging for mass curve
22 disp("energy curve in fig 2")
23 t=[0 3.88 15.88 19.88 23]
24 for j=1:6
25     k(1,j)=a(1,(j+1))
26 end
27 subplot(121);
28 plot(t,m);
29 xtitle("load duration", "hours", "MW")
30 subplot(122);
31 plot(q,ett,-9);
32 xtitle("energy curve", "time", "MWh")

```

Scilab code Exa 2.10 reserve capacity of plant with different factors

```

1 clc
2 disp("example 2.10")
3 egd1=438*10^4;plp=0.2;pcf=0.15; //annual load
    duration ;annual load factor;plant capacity
    factor
4 pml=egd1/(plp*8760)

```

```

5 pc=(pml*plp)/pcf
6 printf("annual load factor =energy generated during
  1 year/(max. load)x8760=%0.1f \n maximum load =
  %dkW",plp,pml)
7 printf("\ncapacity factor =(max.load/plant capacity)
  x(load factor)\n plant capacity =max.load/0.75 =
  %fMW \n reserve capacity =3.333-2.5=%fMW",pc,pc-
  pml)

```

Scilab code Exa 2.11 suggested installed capacity for a plant

```

1 clc
2 disp("example 2.11")
3 p1=10;p2=6;p3=8;p4=7 //peak demands of 4 areas
4 df=1.5;lf=0.65;imdp=0.6;//diversity factor ;annual
  load factor ;ratio of maximum demand
5 p=p1+p2+p3+p4
6 md=p/df
7 ae=md*lf*8760
8 imd=imdp*md
9 ic=md+imd
10 printf(" sum of maximum=%dMW",p)
11 printf("\n maximum demand = sum of max.demands/
  diversity factor =%d/%f = %fMW",p,df,md)
12 printf("\n annual energy =%fMWh \n increase in
  maximum demand =%fMW \n installed capacity =%fMW"
  ,ae,imd,ic)

```




Figure 2.6: load duration curve

Scilab code Exa 2.12 load duration curve

```
1  clc
2  disp("example 2.12")
3  disp("from the above data ,the durations of different
      loads during one week are")
4  aw=[0 5 8 12 13 17 21 24] //given week timings and
      corresponding loads
5  lw=[100 150 250 100 250 350 150]
6  aen=[0 5 17 21 24] //given weakends timing and
      corresponding
7  len=[100 150 200 150]
8  saw=size(aw); saen=size(aen)
9  sae=saw(1,2)-1; saen=saen(1,2)-1
10 for x=1:sae //getting duration
      of load
11     tdw(1,x)=aw(1,x+1)-aw(1,x)
12 end
13 for x=1:saen
14     tden(1,x)=aen(1,x+1)-aen(1,x)
15 end
16 taw=5*tdw //duration of
      entair week
17 taen=2*tden
18 alw=[taw taen;lw len]
19 lwen=[lw len] //arranging load in accending
      order
20 [m n]=gsort(lwen)
21 kn=size(lwen)
22 kld=kn(1,2)
23
24 for x=2:kld
25
26     ldcq(:,x)=alw(:,n(x))
```

```

27     if x>1 then
28         ldcq(1,x)=ldcq(1,x)+ldcq(1,x-1)
29     end
30 end
31
32 plot2d2(ldcq(1,:),ldcq(2,:))
33 printf(" load          duration \n 350MW  4x5
        =20hours \n 250MW  20+8x5=60hours \n 200MW  60+4
        x2 =68hours \n 150MW  68+6x5+15x2 =128hours \n
        100MW  128+6x5+5x2 =168hours")
34 disp("the load duration curve is plotted in fig")
35 disp("the total area under the load duration curve
        is 31600MWh which represents the energy
        consumption in one week.")
36 eclw=ldcq(2,1)*ldcq(1,1)
37 for x=2:1:kld
38     eclw=eclw+(ldcq(2,x)*(ldcq(1,x)-ldcq(1,x-1)))
39 end
40 lf=eclw/(max(lwen)*24*7)
41 printf("total energy consumed is %dWh",eclw)
42 printf("\ntotal maximum energy could consume %dWh",
        eclw/lf)
43 printf("\nload factor =%f",lf)

```

Scilab code Exa 2.13 annual load factor daily load factor and different ratios

```

1  clc
2  disp("example 2.13")
3  dlf=0.825; //daily load factor
4  lptmlp=0.87; //average daily peak load to monthly
    load peak
5  mlptalp=0.78; //average monthly peak load to annual
    load peak

```

```
6 printf("annual load factor =%fx%fx%f=%f.",dlf,lptmlp
    ,mlptalp,dlf*lptmlp*mlptalp)
```

Scilab code Exa 2.14 peak load on different transformers and peak load on feeder

```
1 clc
2 disp("example 2.14")
3 disp("(a)")
4 //given
5 transformer1.motorload=300;transformer1.
    demandform=0.6;tarnsformer1.commercialload
    =100;transformer1.demandfactorc=0.5;transformer1.
    diversityfactor=2.3;transformer2.residentialload
    =500;transformer2.demandfactor=0.4;transformer2.
    diversitryfactor=2.5;transformer3.residentialload
    =400;transformer3.demandfactor=0.5;transformer3.
    diversityfactor=2.0;diversitybtwxmer=1.4
6 peakloadoftransformer1=((transformer1.motorload*
    transformer1.demandform)+(tarnsformer1.
    commercialload*transformer1.demandfactorc))/
    transformer1.diversityfactor
7 peakloadonxmer=(transformer2.residentialload*
    transformer2.demandfactor)/transformer2.
    diversitryfactor
8 peakloadonxmer3=(transformer3.residentialload*
    transformer3.demandfactor)/(transformer3.
    diversityfactor)
9 printf("peak load on transformer 1 =(300x0.6+100x0
    .5)/2.3 =%dkW \npeak load on transformer 2 =%dkW
    \n peak load on transformer 3 =%dkW",
    peakloadoftransformer1,peakloadonxmer,
    peakloadonxmer3)
10 disp("(b)")
```



```
11 peakloadonfeeder=(peakloadoftransformer1+
    peakloadonxmer+peakloadonxmer3)/diversitybtwxmer
12 printf("peak load on feeder =(100+80+100)/1.4 =%dkW"
    ,peakloadonfeeder)
```

Chapter 3

power plant economics

Scilab code Exa 3.1 annual plant cost and generation cost of two different units

```
1  clc
2  disp("example 3.1")
3  totpow=110*10^3 //(kW)
4  uc1=18000;fcr1=0.1;cf1=0.55;fuelcons1=0.7;fuelcost1
   =1500/1000;om1=0.2;utilizationf1=1;
5  uc2=30000;fcr2=0.1;cf2=0.60;fuelcons2=0.65;fuelcost2
   =1500/1000;om2=0.2;utilizationf2=1;
6  //given uck=unit capital cost k;fcrk= fixed charge
   rate of kth unit;cfk=capacity factor at k th unit
   ; omk=annual cost of operating labour ;totpow=
   total power rating of units
7  afc1=fcr1*uc1*totpow;afc2=fcr2*uc2*totpow;
8  e1=8760*cf1*totpow;e2=8760*cf2*totpow;
9  annualfuel1=e1*fuelcons1;annualfuel2=e2*fuelcons2;
10 fc1=annualfuel1*fuelcost1;fc2=annualfuel2*fuelcost2;
11 om11=om1*fc1;om22=om2*fc2;
12 aoc1=fc1+om1;aoc2=fc2+om2;
13 apc1=aoc1+afc1;apc2=aoc2+afc2;
14 gc1=apc1/fc1;gc2=apc2/fc2
15 disp("solution for (a)")
16 printf("\nafc1=Rs. %d\n e1=%dkWh\n annualfual1=%fkg \
```

```

n fc1=Rs.%d \n om1=Rs.%d \n aoc1=Rs.%f \n apc1=Rs
.%f \n gc1=%fkWh\n",afc1,e1,annualfuel1,fc1,om11,
aoc1,apc1,gc1)
17 disp("solution for (b)")
18 printf("\nafc2=Rs.%d\n e2=%dkWh\n annualfual2=%fkg \
n fc2=Rs.%d \n om22=Rs.%d \n aoc2=Rs.%f \n apc2=
Rs.%f \n gc2=%fkWh\n",afc2,e2,annualfuel2,fc2,
om22,aoc2,apc2,gc1)
19 ogc=(apc1+apc2)/(e1+e2)
20
21 printf("\n\nsolution of (c)\nogc=Rs.%f/kWh",ogc)

```

Scilab code Exa 3.2 annual depreciation reserve

```

1 clear
2 clc
3 disp("example 3.2")
4 c=2*10^8; //cost
5 s=0.15; //salvage value
6 ul=25; ///useful value
7 i=0.08; //life of plant
8 disp("solution for (a)")
9 printf("\nannual straight line depreciation reserve
=Rs.%1eperyear\n",c*(1-s)/ul)
10 disp("solution for (b)")
11 it=(i+1)^25-1
12 iit=i/it
13 asdr=c*(1-s)*iit*100
14 printf("\n annual sinking fund depreciation reserve
is =Rs%.3eperyear",asdr)

```

Scilab code Exa 3.3 solving accumulated depreciation

```
1 clear
2 clc
3 disp("example 3.3")
4 cost=2*10^8
5 sal=0.15
6 use=25
7 t=(1-(sal^(1/use)))
8 printf("rate of depreition by fixed percentage method
        =%fpersent",t*100)
9 rd=cost*(1-t)^10
10 printf("\nremaining depreciation at the end of 10th
        year =Rs.%f=Rs.%fx10^8",rd,rd/(10^8))
11 printf("\naccumulated depreciation at the end of 10
        year is Rs.%f =Rs.%fx10^8",cost-rd,(cost-rd)
        /10^8)
```

Scilab code Exa 3.4 load factor verses generation cost

```
1 clc
2 clear
3 disp("example 3 4")
4 p=100 //ratriing of steam station
5 fc=3000 //fixed cost of plant per year
6 rg=0.9 //90 paise per kv generation
```




Figure 3.1: load factor verses generation cost

```

7 uf=1 //utilization factor 1
8 lf=20:20:100 //let load factor be 5 discrete units
9 lm=uf*lf //lwt load MW is as same as lf as
    utilisation factor is 1
10 n=size(lm)
11 fc=fc*ones(1,n(2))
12 op=rg*100*ones(1,n(2))
13 for i=1:n(2)
14     negp(1,i)=lm(i)*8760
15     fcgp(1,i)=fc(i)*10000/negp(i)
16     tgc(1,i)=fcgp(i)+op(i)
17 end
18 plot2d4(lf,tgc)
19 printf("load factor")
20 disp(lf)
21 printf("load MW\n")
22 fcgp=fcgp/100; op=op/100; tgc=tgc/100
23 printf("%dMW\t%dMW\t%dMW\t%dMW\t%dMW",lm(1),lm(2),lm
    (3),lm(4),lm(5))

```

```

24 disp("fixed cost")
25 printf("Rs%d\tRS%d\tRs%d\tRs%d\tRs%d",fc(1),fc(2),fc
(3),fc(4),fc(5))
26 disp("number of KW hrs of energy generated in paise
per unit of energy")
27 printf("%dkWh\t%dkWh\t%dkWh\t%dkWh\t%dkWh",negp(1),
negp(2),negp(3),negp(4),negp(5))
28 disp("fixed cost in paise per unit of energy")
29 printf("Rs%.3f\tRS%.3f\tRs%.3f\tRs%.3f\tRs%.3f",fcgp
(1),fcgp(2),fcgp(3),fcgp(4),fcgp(5))
30 disp("operating cost in paise per unit of energy")
31 printf("Rs%.3f\tRS%.3f\tRs%.3f\tRs%.3f\tRs%.3f",op
(1),op(2),op(3),op(4),op(5))
32 disp("totla generation cost in paise per unit of
energy")
33 printf("Rs%.3f\tRS%.3f\tRs%.3f\tRs%.3f\tRs%.3f",tgc
(1),tgc(2),tgc(3),tgc(4),tgc(5))

```

Scilab code Exa 3.5 generation cost of per unit of energy

```

1 clear
2 clc
3 disp("example 3.5")
4 ic=120 //installed capacity
5 ccppkw=40000 ///capital cost of plant
6 iand=0.15 //interest and depreciation
7 fco=0.64 //fuel consumption
8 fc=1.5//fuel cost
9 oc=50*10^6 //operating cost
10 pl=100//peak load
11 lf=0.6 //load factor
12 al=lf*pl//avarrage load
13 printf(" average load %dMW",al)

```

```

14 eg=al*8760*103//energy generated
15 printf("\n energy generated =%ekWhr",eg)
16 ti=ic*ccppkw //total investment
17 printf("\n total investement Rs.%e",ti)
18 ind=ti*iand*103//interest and depreciation
19 printf("\n investement amd depression is Rs.%e",ind)
20 fcons=eg*fco //fual consumption
21 printf("\n fuel consumption is %ekgper year",fcons)
22 fcost=fcons*fc//fuel cost
23 aco=ti+fcost+ind+oc//annual cost
24 printf("\n fuel cost Rs.%eper year \n annual plant
    cost Rs%eper year \n generation cost Rs%fper
    year",fcost,aco,aco/eg)

```

Scilab code Exa 3.6 comparision between costs of different alternators

```

1 clear
2 clc
3 disp("example 3.6")
4 md=50*103//maximum demand in kW
5 ecy=0
6 pst=600*md+2.5*ecy//public supply tariff equation
7 lfr=0.5; //load factor
8 rc=20*103//reserve capacity
9 cik=30000; //capital investment
10 inad=0.15;///interest and depreciation
11 fuc=0.6;fuco=1.4;oct=0.8//fuel consumption//fuel
    cost//other cost
12 avl=md*lfr;//average load
13 ecy=avl*8760 //energy cosumption per year
14 disp("solution of (a)")
15 printf(" average load = %dkW \n energy consumton =
    %dkWh\n annual expenditure is Rs%dperyear\n",avl,

```

```

    ecy,pst)
16 disp("(b) private steam plant")
17 ict=md+rc; //installed capacity
18 caint=cik*ict; //capital investment
19 iande=inad*caint; //interest and depreciation
20 fuelcon=ecy*fuc; //fuel consumption
21 fucost=fuelcon*fuco; //fuel cost
22 opwe=oct*ecy //other expenditure
23 totex=iande+fucost+opwe//total expenditure
24 printf("\n installed capacity is Rs%d \n capital
    investment is Rs%d \n interest and depreciation
    is Rs.%d \n fuel consumption is Rs.%f \n fuel
    cost is Rs.%f per year \n wage, repair and other
    expenses are Rs%f per year \n total expenditure
    is Rs%e per year",ict,caint,iande,fuelcon,fucost,
    opwe,totex)

```

Scilab code Exa 3.7 overall generation cost per kWh for thermal and hydro plant

```

1  clc
2  clear
3  disp("example 3 7")
4  md=500 //given maximum demand
5  lf=0.5 //load factor
6  hp=7200;he=0.36//operating cost of hydro plant
7  tp=3600;te=1.56 //operating cost of thermal plant
8  teg=md*1000*lf*8760 //total energy generated
9  printf("total energy generated per year %2.2eW",teg)
10 t=(hp-tp)/(te-he) //time of operating using (de/dp)
11 ph=md*(1-t/8760) //from triangle adf
12 pt=md-ph
13 et=pt*t*1000/2
14 eh=teg-et

```



```

15 co=hp*ph*1000+he*eh+tp*pt*1000+te*et
16 ogc=co/teg
17 printf("\n capacity of hydro plant is %dMW \n
    capacity of thermal plant %dMW\n energy
    generatede by hydro plant %dkWh\n energy
    generated by thermal plant %dkWh\n over all
    generation cost is %.3f/kWh",ph,pt,eh,et,ogc)

```

Scilab code Exa 3.16 generation cost of a plant

```

1 clear
2 clc
3 disp(" data 3.16")
4 pu=500*10^3 ;pc=2*pu //plant unit ,plant capacity
5 land=11.865*10^9
6 cicost=30.135*10^9
7 ccost=land+cicost; //capital cost =land cost+civil
    cost
8 plife=25; //plant life
9 ir=0.16; //interest rate
10 ond=1.5*10^-2; // o and mof capital cost
11 gr=0.5*10^-2 //grneral reserve of capital cost
12 calv=4158 //calorific value kj per kg
13 coalcost=990 //caol cost per ton
14 heat=2500 //heat rate kcal/kWh
15 retur=0.08 //return
16 salvage=0
17 plf=0.69 ;auxcons=0.075 //auxiliary consumption
18 disp(" cost calculation ")
19 disp(" using sinking fund depreciation")
20 ande=(ir/((ir+1)^(plife)-1))*100
21 afixcost=ccost*(ir+ond+retur+gr+(ande/100))
22 afcppc=afixcost/pc

```

```

23 printf("annual depretion reserve is %fpersent \n
    annual fixed cost Rs%f \n annual fixed cost per
    Rs%dkWh", ande, afixcost, afcppc)
24 fclco=(heat*coalcost)/(calv*1000)
25 engepc=24*365*plf
26 enavil=engepc*(1-auxcons)
27 gencost=(afcpc/enavil)+fclco
28 printf("\nfuel cost Rs.%f/kWh \nenergy generated per
    kW of plant capacity Rs.%fkWh \nenergy available
    bus bar %fkWh \n generation cost Rs%f perkWh",
    fclco, engepc, enavil, gencost)

```

Scilab code Exa 3.17 to find the generation cost and total annual cost

```

1 clear
2 clc
3 disp("dat 3.17")
4 pco=120*10^3 //3 units of 40MW
5 caco=68*10^8 //6 year of consumption
6 inr=0.16 //intrest rate
7 de=2.5*10^-2 //depreciation
8 oanm=1.5*10^-2//OandM
9 ger=0.5*10^-2//general reserve
10 pllfc=0.6 //plant load facot
11 aucon=0.5*10^-2 //auxiliary consumption
12 tac=caco*(inr+de+oanm+aucon) ///total cost
13 engpy=pco*pllfc*24*365 //energy generatedper year
14 eabb=engpy*(1-ger) //energy available at bus bar
15 geco=tac/eabb //generation cost
16 printf(" total annual costs is Rs%e per year \n
    energy generated per year =%ekWh/year \n energy
    available at bus bar %ekWh/year \n generation
    cost is Rs.%fper kWh", tac, engpy, eabb, geco)

```


Chapter 4

TARIFFS AND POWER FACTOR IMPROVEMENT

Scilab code Exa 4.1 monthly electricity consumption

```
1  clc
2  clear
3  disp('example 4 1')
4  day=30 //days
5  pll=40;nll=5;t11=3 //light load
6  pfl=100;nfl=3;tfl=5 //fan load
7  prl=1*1000 //refrigerator
8  pml=1*1000;nml=1 //misc. load
9  t1=2.74;t11=15//tariff
10 t2=2.70;t22=25 //tariff on 25 units
11 tr=2.32; //reamaining units
12 tc=7.00; //constant charge
13 dis=0.05 //discount for prompt payment
14 te=(pll*nll*t11+pfl*nfl*tfl)*day+prl*day+pml*day
15 tee=te/1000
16 mb=tc+tr*(tee-t11-t22)+t1*t11+t2*t22
17 nmb=mb*(1-dis)
```

```
18 printf("total energy consumption in %d day %dunits \
    nthe monthly bill Rs%.2f \nnet monthly bill Rs%.2
    f",day,tee,mb,nmb)
```

Scilab code Exa 4.2 total electricity bill per year

```
1 clc
2 clear
3 disp('example 4 2')
4 l=100; //connected load
5 md=80; //maximum demand
6 wt=0.6; //working time
7 c=6000; //constant cost
8 t=700; //cost on per kW
9 re=1.8; //rate
10 ec=l*wt*8760 //electricity consumption per year
11 teb=c+md*t+re*ec //total electricity bill per year
12 printf(" energy consumption %dkWh \n total
    electricity bill per year Rs%d",ec,teb)
```

Scilab code Exa 4.3 annual cost operating cost tariff

```
1 clc
2 clear
3 disp('example 4 3')
4 md=160;lff=0.7;dfc=1.7 //maximum demand //load factor
    //diversity factor bt consumers
5 ic=200; //installed capacity
6 ccp=30000 //capital cost of plant per kW
7 ctds=1800*10^6 //capital cost of transmission and
    distribution
```

```

8  idi=0.11 //interest ,depreciation insurance and taxes
    on capital investment
9  fmc=30*10^6 //fixed managerial and general
    maintanance cost
10 ol=236*10^6 //operating labour ,maintanance and
    supplies
11 cm=90*10^6 //cost of metering ,billing and collection
12 eca=0.05 //energy consumed by auxillary
13 el=0.15//energy loss and maintanance
14 p=0.25
15 lf=0.8//load factor
16 ap=0.5 //addition energy for profit
17 disp('a')
18 printf(" capital cost of plant Rs%e \n total capital
    cost Rs%e\n interest ,depereiation system Rs%e ",
    ccp*ic*10^3,ccp*ic*10^3+ctds,(ccp*ic*10^3+ctds)*
    idi)
19 printf("\n sum of maximum demand of consumers energy
    prodused %dMW \n energy produced %ekWh \n energy
    consumed by auxilliries %ekWh\n energy output
    %ekWH \n energy sold to consumer %ekWh\n",md*dfc,
    md*8760*lff*10^3,md*8760*lff*eca*10^3,md*8760*lff
    *10^3*(1-eca),md*8760*lff*10^3*(1-eca)*(1-el))
20 disp('(b)fixed cost')
21 idetc=(ccp*ic*10^3+ctds)*idi
22 tot=idetc+fmc;
23 printf(" interest , deprecition etc Rs%e per year\n
    managerial and maintence Rs%.eper year \n total \
    t Rs%e ",idetc,fmc,tot)
24 pro=p*tot
25 gtot=tot+pro
26 printf("\n profit@%d \tRs%eper year \n grand total
    Rs%e per year",p*100,pro,gtot)
27 disp('Operating cost')
28 tot2=ol+cm
29 pro2=tot2*p
30 gtot2=tot2+pro2
31 printf(" Operating labour ,supplies maintenance etc

```

```

Rs.%eper year \n metering , billing etc Rs%eper
year\n total\t\tRs%e per year\n profit \t Rs%eper
year \n grand total \t Rs%e per year",ol,cm,tot2
,pro2,gtot2)
32 disp('tariff')
33 co=gtot/(md*dfc*1000)
34 es=md*8760*lff*10^3*(1-eca)*(1-el)
35 cs=gtot2/es
36 printf(" cost per kW \tRs%e \n cost per kWh \tRs%e",
co,cs)
37 disp('(b)')
38 ep=md*1000*8760*lf
39 printf(" energy produced %ekWh \n energy consumed by
auxiliaries %ekWh/year \n energy output of plant
%ekWh \n energy sold to consumer %ekWh",ep,ep*
eca,ep*(1-eca),ep*(1-eca)*(1-el))
40 estc=ep*(1-eca)*(1-el)

```

Scilab code Exa 4.4 monthly bill and average tariff per kWh

```

1 clc
2 clear
3 disp('example 4 4')
4 v=230;ec=2020; //voltage //energy consumption
5 i=40;pf=1;t=2;c=3.5;rc=1.8;mon=30; //current/power
factor/time/cost/reamining cost/month
6 ecd=v*i*pf*t*mon/1000 //energy corresponding to
maximum demand
7 cost=ecd*c
8 ren=ec-ecd
9 rcost=ren*rc

```

```

10 tmb=cost+rcost
11 at=tmb/ec
12 printf(" energy corresponding to maximum demand
    %dkWh \n cost of above energy Rs%d \n remaining
    energy %dkWh \n cost of reamaining energy Rs%.1f
    \n total monthly bill Rs%.1f\n avarage tariff
    Rs%.3fper kWh",ecd ,cost ,ren ,rcost ,tmb ,at)

```

Scilab code Exa 4.5 better consumption per year

```

1 clc
2 clear
3 disp('example 4 5')
4 t1=3000;t11=0.9 //cost equation
5 t2=3; //rate
6 x=t1/(t2-t11)
7 printf("if energy consumption per month is more than
    %.1fkWh,\n tariff is more suitable",x)

```

Scilab code Exa 4.6 avarage energy cost in different case

```

1 clc
2 clear
3 disp("example 4 6")
4 aec=201500 //annual energy consumption
5 lf=0.35//load factor constnt
6 t=4000//tariff
7 tmd=1200//tariff for maximum demand
8 t3=2.2
9 lfb=0.55 //load factor improved
10 ecd=0.25//energy consumption reduced

```



```

11 md=aec/(8760*lf)
12 yb=t+md*tmd+t3*aec
13 mdb=aec/(8760*lfb)
14 ybb=t+mdb*tmd+t3*aec
15 ne=aec*(1-ecd)
16 md3=ne/(8760*lf)
17 ybc=t+md3*tmd+t3*ne
18 aeca=yb/aec
19 aecb=ybb/aec
20 aecc=ybc/ne
21 disp('a')
22 printf("maximum demand %.2fkW \n yearly bill Rs.%d
        per year \n(b)\n maximum demand %.2fkW \n yearly
        bill Rs.%dper year",md,yb,mdb,ybb)
23 disp("c")
24 printf(" new energy %dkWh \n maximum demand %.2fkW \
        n yearly bill Rs.%dper year \n average energy
        cost in case a Rs%.4fper kWh \n average energy
        cost in case b Rs%.3fper kWh\n average energy
        cost in case c Rs%.3fper kWh ",ne,md3,ybc,aeca,
        aecb,aecc)

```

Scilab code Exa 4.7 selection of cheaper transformer

```

1  clc
2  clear
3  disp('example 4 7')
4  pl1=20;pf1=0.8;t1=2000//load in MVA //power factor
   //duration
5  pl2=10;pf2=0.8;t2=1000//load in MVA //power factor
   //duration
6  pl3=2;pf3=0.8;t3=500//load in MVA //power factor //
   duration

```

```

7 pt=20 ///transformar power rating
8 fte=0.985;ste=0.99 ///full load efficiency for first
  and second transformer
9 ftl=120;stl=90 //core loss inKW for first and
  second transformer
10 cst=200000;///cost of second transformer with
  compared with first transformer
11 aid=0.15;///annual interest and depreciation
12 ce=0.8 //cost of energy
13 tfl=pt*(1-fte)*1000//total full load
14 fle=ftl-ftl //full load copper loss
15 elc=fle*t1+(fle*t2/(pt/pl2)^2)+(fle*t3/(pt/pl3)^2)
  //energy loss due to copper loss
16 eli=ftl*(t1+t2+t3)//energy loss due to iron loss
17 celo=(elc+eli)*ce //cost of energy loss
18 disp(" first transformer")
19 printf(" total full load losses %dkW \n full load
  copper losses %dkW \n energy loss due to copper
  losses %dkWh/year\n energy loss due to iron
  losses %dkWh/year \n cost of energy losses
  Rs%dper year",tfl,fle,elc,eli,celo)
20 stfl=pt*(1-ste)*1000//total full load
21 sle=stfl-stl//full load copper loss
22 selc=sle*t1+(sle*t2/(pt/pl2)^2)+(sle*t3/(pt/pl3)^2)
  //energy loss due to copper loss
23 seli=stl*(t1+t2+t3)//energy loss due to iron loss
24 scelo=(selc+seli)*ce//cost of energy loss
25 disp(" second transformer")
26 printf(" total full load losses %dkW \n full load
  copper losses %dkW \n energy loss due to copper
  losses %dkWh/year\n energy loss due to iron
  losses %dkWh/year \n cost of energy losses
  Rs%dper year",stfl,sle,selc,seli,scelo)
27 aidc=stfl*aid*1000
28 tybc=aidc+scelo
29 printf("additional interest and depreciation due to
  higher cost of second transformer Rs%d \n total
  yearly charges for second transformer Rs%d per

```

```
year",aidc,tybc)
```

Scilab code Exa 4.8 most economical power factor and rating of capacitor bank

```
1 clc
2 clear
3 disp('example 4 8')
4 p=500 //load
5 pf=0.8//power factor
6 t=400 //tariff
7 md=100 //maximum demand tariff
8 ccb=600 //cost of capacitor bank
9 id=0.11//interest and deprecistion
10 sd=ccb*id/t//sin(ph2)
11 d2=asind(sd)
12 pf2=cosd(d2)
13 kva=p*(tand(acosd(pf))-tand(d2))
14 printf(" the most economic power factor %.3f lagging
        \n kvar requirement %.2fkVAR",pf2,kva)
```

Scilab code Exa 4.9 maximum load at unity power factor which can be supplied by th

```
1 clc
2 clear
3 disp("example 4 9")
4 l1=300; //load and power factor for three different
        loads
5 pf1=1;
6 l2=1000;
```

```

7 pf2=0.9;
8 l3=1500;
9 pf3=0.8
10 printf(" for %dkW unit power factor load \n power
    factor angle %.f\n reactive power %.fkvr",l1,
    acosd(pf1),l1*(tand(acosd(pf1))))
11 printf(" \nfor %dkW unit power factor load \n power
    factor angle %.2f\n reactive power %.2fkvr",l2,
    acosd(pf2),l2*(tand(acosd(pf2))))
12 printf(" \nfor %dkW unit power factor load \n power
    factor angle %.2f\n reactive power %.2fkvr",l3,
    acosd(pf3),l3*(tand(acosd(pf3))))
13 t1=l1+l2+l3
14 tt=l3*(tand(acosd(pf3)))+l2*(tand(acosd(pf2)))+l1*(
    tand(acosd(pf1)))
15 printf("\n total kW \t%dkW\n total kVAR %.1fkVAR \n
    total kVA %.2fkVA \n overall power factor %.3
    flagging",t1,tt,(t1^2+tt^2)^0.5,t1/(t1^2+tt^2)
    ^0.5)
16 printf("\n the maximum unity power factor load which
    yhe station can supply is equal to the kVA i.e.%
    .2fkVR", (t1^2+tt^2)^0.5)

```

Scilab code Exa 4.10 kvar rating of star connected capacitor and capacitance for p

```

1 clc
2 clear
3 disp("example 4 10")
4 v=400//voltage
5 i=25///current
6 pf=0.8//at power factor
7 pf2=0.9//over all power factor
8 kw=v*i*pf*sqrt(3)/1000

```

```

9 printf("kw rating of induction motor %.2fkW",kw)
10 dm=acosd(pf)
11 rp=kw*tand(dm)
12 printf("\n power factor angle %.2f \n reactive power
    %.2fkVR",dm,rp)
13 fdm=acosd(pf2)
14 rp2=kw*tand(fdm)
15 printf("\n final power factor %.2f \n final
    reactance power %.2fkVR",fdm,rp2)
16 ckvb=rp-rp2
17 cc=ckvb*1000/(sqrt(3)*v)
18 vc=v/sqrt(3)
19 xc=vc/cc
20 f=50
21 cec=1*10^(6)/(xc*2*pi*f)
22 printf("\n kvar rating of capacitor bank %.4f \n
    current through each capacitor %.2fA\n voltage
    across each capacitor %.2f \n reactance of each
    capacitor %.2fohm \n capacitance of each
    capacitance %.2fuf",ckvb,cc,vc,xc,cec)

```

Scilab code Exa 4.11 kva and power factor of synchronous motor

```

1 clc
2 clear
3 disp("example 4 11")
4 v=400 //line voltage
5 i=50 //line current
6 pf=0.8 //at power factor
7 pf2=0.95 // overall power factor
8 sm=25 //hp of synchronous motor
9 e=0.9 //efficiency
10 kwri=v*i*pf*sqrt(3)/1000

```

```

11 kvari=v*i*sqrt(3)/1000
12 karri=(-kwri^2+kvari^2)^0.5
13 kws=sm*735.5/(e*1000)
14 tkw=kwri+kws
15 printf(" kw rating of installation %.1fkW \n kVA
        rating of installation %.2fkva \n kVAR rating %.2
        fkvar \n kw input to synchronous motor %.2fkW \n
        total kw=%.2f\n",kwri,kvari,karri,kws,tkw)
16 pd=acosd(pf2)
17 tkr=tkw*tand(pd)
18 krsm=tkr-karri
19 kasm=(kws^2+krsm^2)^0.5
20 pfsm=kws/kasm
21 if krsm<0 then
22     ch=char('capacitor')
23     ich=char('leading')
24 else
25     ch=char('inductive')
26     ich=char('lagging')
27 end
28 printf(" overall power factor angle %.2fkW \n total
        kvar %.2fkvar \n kvar of synchronous motor %.2
        fkvar %c \n kva of synchronous motor %.2fkva \n
        power factor of synchronous motor %.2f %c",pd,
        tkr,krsm,ch,kasm,pfsm,ich)

```

Scilab code Exa 4.12 parallel operation of synchronous and induction motor under d

```

1 clc
2 clear
3 disp("example 4 12")

```

```

4 psm=100 //power of synchronous motors
5 pim=200 //power of induction motor
6 v=400 //voltage
7 pff=0.71;pp=-1//power factor
8 rsm=0.1 //resistance of synchronous motor
9 rt=0.03 //resistance of cable
10 pf(1)=1;p(1)=1 //power factor in a
11 pf(2)=0.8;p(2)=1 //power factor in b
12 pf(3)=0.6;p(3)=1 //power factor in c
13 i1=pim*1000/(v*pff*sqrt(3))
14 i11=i1*(complex(pff,pp*sind(acosd(pff))))
15 i2f=psm*1000/(v*sqrt(3))
16 ch=['a' 'b' 'c']
17 for i=1:3
18     printf("\n (%c)",ch(i))
19     d=acosd(pf(i))
20     it(i)=i11(1)+complex(i2f,(p(i)*i2f*tand(d)))
21     opf(i)=cosd(atan(imag(it(i))/real(it(i))))
22     clsm=3*((i2f)^2)*rsm
23     clt=3*(abs(it(i))^2)*rt/1000
24     printf("\n total current %.2f %.fjA \n overall
        power factor %.3f lagging \n copper losses in
        synchronous motor %.fW \n copper losses in
        cable %.2fKW",it(i),imag(it(i)),opf(i),clsm,
        clt)
25 end
26 disp("(d)")
27 printf("copper loss of synchronous motor this is
        evidently minimum when tand=%d cosd=%d",0,1)

```

Scilab code Exa 4.13 finding power factor and load on different generator

```

1 clc
2 clear
3 disp('example 4 13')

```

```

4 p=2//constant output in MW
5 pf=0.9//power factor
6 pa=10//load
7 pb=5
8 pfb=0.8//power factor at load of 5MW
9 td=tand(acosd(pf))
10 go=p*(1-td*i)
11 op=0.8
12 tp=tand(acosd(pfb))
13 printf("power factor of induction generator is
        leading therefor induction generator output %d%.2
        fiMVA /n (a) \n",real(go),imag(go))
14 t1=pa*(1+tp*i)
15 sg=t1-go
16 da=atand(imag(sg)/real(sg))
17 printf(" total load %d+%.1fiMW \n synchronous
        generator load %d+%.3fiMW \n\t\tt=%fMW at angle
        %.2f \n power factor of synchronous generator is
        %.2 flagging",real(t1),imag(t1),real(sg),imag(sg),
        abs(sg),da,cosd(da))
18 t11=pb*(1+tp*i)
19 sg1=t11-go
20 da1=atand(imag(sg1)/real(sg1))
21 disp(" (b) ")
22 printf(" total load %d+%.1fiMW \n synchronous
        generator load %d+%.3fiMW \n\t\tt=%fMW at angle
        %.2f \n power factor of synchronous generator is
        %.2 flagging",real(t11),imag(t11),real(sg1),imag(
        sg1),abs(sg1),da1,cosd(da1))

```

Scilab code Exa 4.14 loss if capacitor is connected in star and delta

```
1 clc
```



```

2 clear
3 disp("example 4 14")
4 c=40*10^(-6) //bank of capacitors in farads
5 v=400 //line voltage
6 i=40///line current
7 pf=0.8//power factor
8 f=50//line frequency
9 xc=1/(2*%pi*f*c)
10 ic=v/(sqrt(3)*xc)
11 il=i*(pf-sind(acosd(pf)))*%i
12 til=il+%i*ic
13 od=atand(imag(til)/real(til))
14 opf=cosd(od)
15 nlol=(abs(od)/i)^2
16 disp("a")
17 printf(" line current of capacitor bank %.1fA \n
        load current %d%diA \n total line current %d%.1
        fjA \n overall p.f %.3f \n new line loss to old
        line loss %.3f",ic,real(il),imag(il),real(til),
        imag(til),opf,nlol)
18 pcb=(v/xc)
19 printf("\n phase current of capacitor bank %.3fA",
        pcb)
20 lcb=pcb*sqrt(3)
21 printf("\n line current of capacitor bank %.1fA",lcb
        )
22 tcu=il+lcb*%i
23 printf("\n total current %d%.1fjA =%.2fA at an angle
        %.2f",tcu,imag(tcu),abs(tcu),atand(imag(tcu)/
        real(tcu)))
24 pf2=cosd(atand(imag(tcu)/real(tcu)))
25 printf("\n power factor %.1f \n ratio of new line
        loss to original loss %.3f",pf2,(abs(tcu)/i)^2)

```

Scilab code Exa 4.15 percentage reduction in line loss with the connection of capacitor bank

```
1 clc
2 clear
3 disp("example 4 15")
4 p=30 //b.h.p of induction motor
5 f=50 //line frequency
6 v=400 //line voltage
7 e=0.85 //efficiency
8 pf=0.8 //power factor
9 i=p*746/(v*e*pf*sqrt(3))
10 i=i*complex(pf,-sind(acosd(pf)))
11 ccb=imag(i)/sqrt(3)
12 xc=v/ccb
13 c=10^6/(2*f*%pi*xc)
14 prl=((abs(i)^2-real(i)^2)/abs(i)^2)*100
15 printf(" current drawn by motor is %.1fA \n the line
        loss will be minimum when i is minimum.the
        minimum value of i is %dA and occurs when the
        capacitor bank draws a line current of %djA \n
        capacitor C %.2fuf \n percentage loss reduction
        %d",abs(i),i,imag(i),abs(c),prl)
```

Scilab code Exa 4.16 kva of capacitor bank and transformer and etc

```
1 clc
2 clear
3 disp("example 4 16")
4 po=666.66 //power
5 f=50 //frequency
6 v=400 //voltage
7 pf=0.8 ;p=-1 //power factor
8 pf2=0.95;p2=-1 //improved power factor
```

```

9  vc=2200 //capacitor voltage
10 rc=vc
11 il=po*1000/(v*pf*sqrt(3))
12 il1=il*(complex(pf,p*sind(acosd(pf))))
13 i2c=il*pf
14 tad=tand(acosd(pf2))
15 i2=complex(i2c,i2c*tad*p2)
16 printf(" load current il %.2f%.2fA \n load current
        current on improved power factor %.2f%.2fjA",il1,
        imag(il1),i2,imag(i2))
17 disp(" (a) ")
18 ic=abs(il1-i2)
19 ilc=ic*v/vc
20 pic=ilc/sqrt(3)
21 xc=vc/pic
22 ca=10^6/(2*pi*f*xc)
23 printf(" line current of %dV capacitor bank %.2fA\n
        line current of %d capacitor bank %.2fA \n phase
        current of capacitor bank %.2fA \n reactance %.2f
        \n capacitance %.2fF*10^(-6)",v,ic,vc,ilc,pic,xc
        ,ca)
24 disp(" (b) ")
25 kr=3*vc*pic/1000
26 printf(" kVA rating %.1fkVA \n kVA rating of
        transformer to convert %dV to %dV will be the
        same as the kVA rating of capacitor bank",kr,v,vc
        )
27 pl=100*(abs(il1)^2-abs(i2)^2)/abs(il1)^2
28 printf(" percentage reduction in losses %d percent",
        pl)
29 disp(" (d) ")
30 pi=ic/sqrt(3)
31 xcc=v/pi
32 cc=1*10^6/(2*pi*f*xcc)
33 roc=ca/cc
34 printf(" phase current %.1fA \n reactance %.2fohm \n
        capacitance %.2f*10^-6F \n ratio of capacitance
        %.3f",pi,xcc,cc,roc)

```

Scilab code Exa 4.17 MVA rating of three winding of transformer

```
1 clc
2 clear
3 disp("example 4 17")
4 v1=132//line voltage at primary
5 v2=11//line voltage at secondary
6 p=10 //power
7 pf=0.8 //power factor
8 mva=p*(complex(pf,sind(acosd(pf))))
9 printf(" MVA rating of secondary = %dMVA =%d+%djMVA
  \n ",p,mva,imag(mva))
10 printf("\n since the power factor at primary
  terminals is unity ,rating of primary need be
  %dMVA only \n the tertiary will supply capacitor
  curren.since p.f is to be raised to 1 ,the mav
  compensation needed is 6MVA so rating of
  teritiary is %dMVA",mva,imag(mva))
```

Scilab code Exa 4.18 load power and power factor of 3 ph alternator

```
1 clc
2 clear
3 disp("example 4 18")
4 v=11 //line voltage
5 f=50//line frequency
6 l=400 //load of alternator
```

```

7 pf=0.8 //power factor
8 e=0.85//efficiency
9 p=1/pf
10 lo=1+p*sind(acosd(pf))*%i
11 disp("a")
12 printf("when pf is rased to 1 the alternator can
        supply %dkW for the same value of armture current
        hence it can supply %dkW to synchronous motor",p
        ,p-1)
13 disp("b")
14 printf("b.h.p =%.2fHP" ,100*e/0.746)
15 kvam=p-lo
16 td=atand(imag(kvam)/real(kvam))
17 pff=cosd(td)
18 printf("\ncosd=%.3fleading" ,pff)

```

Scilab code Exa 4.19 maintaining of poer factor using capacitor

```

1 clc
2 clear
3 kw=100 //let kw=100kw
4 pf=0.6 //power factor
5 pf2=0.8 //power factor
6 kvar=kw*tand(acosd(pf))
7 kvar2=kw*tand(acosd(pf2))
8 ckar=((kvar-kvar2))/10
9 ck=round(ckar)*10
10 disp("example 4 19")
11 printf("capacitor kVAR required for %dkW\n load for
        same power factor improvement %dkVAR",round(ckar)
        ,ck)
12 pff=0.95:-0.05:0.4
13 pff=200*pff

```

```
14 n=size(pff)
15 z=zeros(1,n(2))
```

Scilab code Exa 4.20 maintaining of poer factor using capacitor

```
1 clc
2 clear
3 disp("example 4 20")
4 p=160 //kva for transformer
5 pf=0.6 //power factor
6 el=96 //effective load
7 eli=120 //effective load increase
8 rc=eli*(tand(acosd(pf))-tand(acosd(eli/p)))
9 opf=eli/p
10 printf(" required capacitor kVAR %dKVAR \n overall
    power factor %.2f \n it is seen that point d is
    on %.2f line",rc,opf,opf)
```

Scilab code Exa 4.21 difference in annual fixed charges of consumer for change in

```
1 clc
2 clear
3 disp("example 4 21")
4 md=800 //maximum demand
5 pf=0.707 //power factor
6 c=80 //cost
7 p=200 //power
```

```

8 e=0.99//efficiency
9 pff=0.8 //fullload pf
10 ikva=md/pf
11 iaafc=(round(ikva*100)*(c)/100)
12 rsm=ikva*pf
13 act=p*(0.7355)/e
14 at=-act*sind(acosd(pff))
15 tkw=rsm+act
16 tkvr=rsm+at
17 tkva=(tkw^2+tkvr^2)^0.5
18 ikvad=tkva-ikva
19 infc=ikvad*c
20 printf(" initial kVA %.2fkVA \n initial annual fixed
charges Rs%.1f \n after installation of
synchronous motor reactive power of induction
motor %dkVars\n active power input of
synchronuous motor %.2fkW\n reactive power input
to synchronuous motor %.2fkVAR \n total kW %.2fkW
\n total kVars %.2fkVARS \n total kVA %.2fkVA \n
increase in KVA demand %.2fkVA\n increase in
annual fixed charges Rs%.1f ",ikva,iaafc,rsm,act,
at,tkw,tkvr,tkva,ikvad,infc)

```

Scilab code Exa 4.22 finding annual cost and difference in annual cost in two units

```

1 clc
2 clear
3 disp("example 4 22")
4 t=16//working time
5 d=300 //working days
6 hv=1;hvmd=50 //tariff on high voltage
7 lv=1.1;lvmd=60 //tariff on low voltage
8 al=250//avarage load
9 pf=0.8//power factor
10 md=300 //maximum demand

```

```

11 hvec=500 //cost of hv equipment
12 l=0.05 //loss of hv equipment
13 id=0.12 //interest and deprecistion
14 ter=al*md*t
15 mdv=md/pf
16 printf(" total energy requirement %2.2ekWH \n
    maximum demand %dKVA",ter,mdv)
17 disp("(a)HV supply")
18 chv=mdv*hvec
19 idc=chv*id
20 ere=ter/(1-l)
21 dch=mdv*lvmd
22 ech=round(ere*hv/1000)*1000
23 tanc=ech+dch+idc
24 printf(" cost of HV equipment Rs%e\n interest and
    depreciation charges Rs%d \n energy received
    %ekWh\n demand charges Rs%d \n energy charges
    Rs%2e \n total annual cost Rs%d",chv,idc,ere,dch,
    ech,tanc)
25 disp("(b) LV supply")
26 lvdc=mdv*lvmd
27 lvec=ter*lv
28 lvtac=lvec+lvdc
29 lvdac=lvtac-tanc
30 printf(" demand charges Rs%d \n energy charges Rs%2.
    e \n total annual cost Rs%d \n difference in
    annual cost Rs%d",lvdc,lvec,lvtac,lvdac)

```

Chapter 5

SELECTION OF PLANT

Scilab code Exa 5.1 selection of plant on criteria of investment other

```
1 clear
2 clc
3 disp("solution of exp 5.1")
4 aerpe=100*10^6
5 md=25*10^3
6 function [u]=ucc(dd,e)
7     u=600*dd+0.3*e //rs per kW
8     endfunction
9 sc=30*10^3
10
11 a.cci=9000//per kW
12 a.shr=4000
13 b.cci=10500
14 b.shr=3500
15 c.cci=12000
16 c.shr=3000
17 salc=3000
18 sal=2280
19 sh=10
```

```

20 tax=0.04
21 ins=0.5*10^-2
22 cir=0.07
23 hv=5000//l cal per kg
24 fuc=225//rs per ton
25 acsnm=150000//for each plan
26 pl=20
27 dr=cir/((cir+1)^pl-1)
28 tfcr=cir+dr+tax+ins
29 printf("depreciation rate %f \n total fixed rate =%f
      ",dr,tfcr)
30 a.ci=a.cci*sc;b.ci=b.cci*sc;c.ci=c.cci*sc
31 a.afca=a.ci*tfcr;b.afca=b.ci*tfcr;c.afca=c.ci*tfcr
32 a.afuc=a.shr*fuc*10^8/(hv*10^3)
33 b.afuc=b.shr*fuc*10^8/(hv*10^3)
34 c.afuc=c.shr*fuc*10^8/(hv*10^3)
35 ass=12*(salc+sh*sal)
36 tota=a.afca+ass+a.afuc+acsnm
37 totb=b.afca+ass+b.afuc+acsnm
38 totc=c.afca+ass+c.afuc+acsnm
39 printf("\nannual fixed cost of a is Rs%d fuel
      cost of plan a is Rs%d and total cost of a is
      Rs%d",a.afca,a.afuc,tota)
40 printf("\nannual fixed cost of b is Rs%d fuel cost
      of plan b is Rs%d and total cost of b is Rs%d",b
      .afca,b.afuc,totb)
41 printf("\nannual fixed cost of c is Rs%d fuel cost
      of plan c is Rs%d and total cost of c is Rs%d",c
      .afca,c.afuc,totc)
42
43 ppt=ucc(md,aerpe)
44 printf("\nannual cost of purchasing electricity from
      utility is Rs600x%d+0.3x%.1e is Rs%d",md,aerpe,
      ppt)

```

Scilab code Exa 5.2 selection of plant on criteria of investment with out interest

```
1 clear
2 clc
3 disp("example 5.2")
4 aer=100*10^6
5 md=25*10^3
6 function [u]=ucc(dd,e)
7     u=600*dd+0.3*e //rs per kW
8     endfunction
9 p=30*10^3
10 ap=9000//per kW
11 ahr=4000
12 bp=10500
13 bhr=3500
14 cp=12000
15 chr=3000
16 salc=3000
17 sal=2280
18 sh=10
19 t=0.04
20 i=0.5*10^-2
21 r=0.07
22 hv=5000//l cal per kg
23 fuc=225//rs per ton
24 mc=150000//for each plan
25 n=20
26 dr=r/((r+1)^n-1)
27 pwf=r/(1-(r+1)^(-n))
28 printf("percent of worth factor is %f",pwf)
29 afc=ahr*fuc*10^8/(hv*10^3)
30 bfc=bhr*fuc*10^8/(hv*10^3)
```

```

31 cfc=chr*fuc*10^8/(hv*10^3)
32 ass=12*(salc+sh*sal)
33 aaoc=ass+mc+afc
34 baoc=ass+mc+afc
35 caoc=ass+mc+afc
36 ai=ap*p;bi=bp*p;ci=cp*p
37 atac=(t+i)*ap*p+aaoc
38 btac=(i+t)*bp*p+baoc
39 ctac=(i+t)*cp*p+caoc
40 uts=ucc(md,aer)
41 apw=atac/pwf;bpw=btac/pwf;cpw=ctac/pwf;utss=uts/pwf
42 ta=apw+ai;tb=bpw+bi;tc=cpw+ci
43 printf("\nannual cost excluding interest and \
    ndepreciation of a \t\tRs%d \npercent worth
    factor \t\t%f \npercent worth annual cost of a
    is Rs%d \n investement of a is \tRs%d \n total
    percent worth of a is \t%d",atac,pwf,apw,ai,ta)
44 printf("\n\n annual cost excluding interest and \
    ndepreciation of b \t\tRs%d \npercent wort factor
    \t\t%f \npercent worth annual cost of b is Rs%d
    \n investement of b is \tRs%d \n total percent
    worth of b is \t%d",btac,pwf,bpw,bi,tb)
45 printf("\n \nannual cost excluding interest and \
    ndepreciation of c \t\tRs%d \npercent wort factor
    \t\t%f \npercent worth annual cost of c is Rs%d
    \n investement of c is \tRs%d \n total percent
    worth of c is \t%d",ctac,pwf,cpw,ci,tc)
46 printf("\n \nannual cost excluding interest and \
    ndepreciation of utility service \tRs%d \npercent
    wort factor \t\t\t%f \npercent worth annual
    cost of utility service is Rs%d \n investement of
    utility service is \t\t nill \n total percent
    worth of utility service is %d",uts,pwf,utss,utss
    )
47 printf("\n\n\tsince the present worth of the utility
    service is the minimum,it is the obvious choice
    \nout of the other plans,plan A is the best since
    it has the lowest present worth")

```

Scilab code Exa 5.3 calculate the capital cost

```
1 clear
2 clc
3 disp("example 5.3")
4 aer=100*10^6 //from example 5.1
5 md=25*10^3
6 function [u]=ucc(dd,e)
7     u=600*dd+0.3*e //rs per kW
8     endfunction
9 p=30*10^3
10 ap=9000//per kW
11 ahr=4000
12 bp=10500
13 bhr=3500
14 cp=12000
15 chr=3000
16 salc=3000
17 sal=2280
18 sh=10
19 t=0.04
20 i=0.5*10^-2
21 r=0.07
22 hv=5000//l cal per kg
23 fuc=225//rs per ton
24 mc=150000//for each plan
25 n=20
26 dr=r/((r+1)^n-1)
27 pwf=r/(1-(r+1)^(-n))
28 uts=ucc(md,aer)
29 afc=ahr*fuc*10^8/(hv*10^3)
30 bfc=bhr*fuc*10^8/(hv*10^3)
```

```

31 cfc=chr*fuc*10^8/(hv*10^3)
32 ass=12*(salc+sh*sal)
33 aaoc=ass+mc+afc
34 baoc=ass+mc+bfc
35 caoc=ass+mc+cfc
36 aw=([[dr+t+i]*ap*p+aaoc]/r)+ap*p
37 bw=([[dr+t+i]*bp*p+baoc]/r)+bp*p
38 cw=([[dr+t+i]*cp*p+caoc]/r)+cp*p
39 utt=uts/r+p
40 printf("\n plan A is \t\tRs.%d \n plan B is \t\tRs.
      %d \n planC is \t\tRs.%d \n utility services is \
      tRs%d",aw,bw,cw,utt)
41 disp("the utility service has the lowest capitalized
      cost and is the obvious choice. Out of the other
      plans ,plan A is the best")

```

Scilab code Exa 5.4 rate of return method for best plan

```

1 clear
2 clc
3 disp("example 5.4")
4 aer=100*10^6
5 md=25*10^3
6 utse=6600*10^4
7 p=30*10^3
8 ap=9000 //per kW
9 ahr=4000
10 bp=10500
11 bhr=3500
12 cp=12000
13 chr=3000
14 salc=3000
15 sal=2280

```

```

16 sh=10
17 t=0.04
18 i=0.5*10^-2
19 r=0.07
20 hv=5000//l cal per kg
21 fuc=225//rs per ton
22 mc=150000//for each plan
23 n=20
24 dr=r/((r+1)^n-1)
25 pwf=r/(1-(r+1)^(-n))
26 afc=ahr*fuc*10^8/(hv*10^3)
27 bfc=bhr*fuc*10^8/(hv*10^3)
28 cfc=chr*fuc*10^8/(hv*10^3)
29 ass=12*(salc+sh*sal)
30 aaoc=ass+mc+afc
31 baoc=ass+mc+bfc
32 caoc=ass+mc+cfc
33
34 sol.a.totalannualcost=(t+i)*ap*p+aaoc
35 sol.b.totalannualcost=(i+t)*bp*p+baoc
36 sol.c.totalannualcost=(i+t)*cp*p+caoc
37
38 sol.a.pinvestement=ap*p;sol.b.pinvestement=bp*p;sol.
    c.pinvestement=cp*p
39
40 sol.a.annuity=utse-sol.a.totalannualcost;
41 sol.b.annuity=utse-sol.b.totalannualcost;
42 sol.c.annuity=utse-sol.c.totalannualcost;
43
44 sol.a.ratioaandp=sol.a.annuity/sol.a.pinvestement;
45 sol.b.ratioaandp=sol.b.annuity/sol.b.pinvestement;
46 sol.c.ratioaandp=sol.c.annuity/sol.c.pinvestement;
47 function [R]=alt(r)
48     R=abs(r/(1-wr))
49 endfunction
50 ra=round((sol.a.ratioaandp)*100)
51     rb=round((sol.b.ratioaandp)*100)
52     rc=round((sol.c.ratioaandp)*100)

```

```

53 for x=-0.12:0.001:-0.07 //for iteration
54     wr=(1+x)^n
55     re=alt(x)
56     re=(round(re*100))
57         if re==ra then
58             sol.a.return=(abs(x)*100)
59         end
60         if re==rb then
61             sol.b.return=(abs(x)*100)
62         end
63         if re==rc then
64             sol.c.return=(abs(x)*100)
65         end
66     end
67     disp("for (a)")
68     printf("total annual cost Rs.%d\ninvestment Rs.%d\
nannuity Rs%d \nratio of a and b %f \nrate of
return %.1fpercent",sol.a.totalannualcost,sol.a.
pinvestment,sol.a.annuity,sol.a.ratioandp,sol.a
.return)
69     disp("for (b)")
70     printf("total annual cost Rs.%d\ninvestment Rs.%d\
nannuity Rs%d \nratio of a and b %f \nrate of
return %.1fpercent",sol.b.totalannualcost,sol.b.
pinvestment,sol.b.annuity,sol.b.ratioandp,sol.b
.return)
71     disp("for (c)")
72     printf("total annual cost Rs.%d\ninvestment Rs.%d\
nannuity Rs%d \nratio of a and b %f \nrate of
return %.1fpercent",sol.c.totalannualcost,sol.c.
pinvestment,sol.c.annuity,sol.c.ratioandp,sol.c
.return)
73 sb=sol.b.annuity-sol.a.annuity
74 sc=sol.c.annuity-sol.b.annuity
75 ib=sol.b.pinvestment-sol.a.pinvestment
76 ic=sol.b.pinvestment-sol.a.pinvestment
77 rcb=sb/ib;rcc=sc/ic;
78 printf("\nsaving in annual cost excluding interest

```



```

    and depreciation B over A \t %d C over A \t %d",
    sb,sc)
79 printf("\nadditional investement P is \t\t\t\tB over
    A \t %d C over A \t %d",ib,ic)
80 printf("\nrate of saving to investement \t\t\t\t\
    tAoverB \t\t %f BoverC \t%f",rcb,rcc)
81 printf("\nrate of return on capital investement\n
    evidently plan A is the best \t\t\t\t\tA over B \
    tNegative B over C \tNegative")

```

Chapter 7

THERMAL POWER PLANTS

Scilab code Exa 7.1 calculation of energy input to the thermal plant and output fr

```
1 clear
2 clc
3 disp(" exanple7.1")
4 pow=100*10^6
5 calv=6400
6 threfff=0.3
7 elcefff=0.92
8 kcal=0.239*10^-3
9 eo=pow*3600
10 ei=eo/(threfff*elcefff)
11 eikc=ei*kcal
12 colreq=eikc/6400
13 printf("energy output in 1 hour is %eWatt.sec ",eo);
14 printf("\nenergy input in one hour is %ejoules Watt.
    sec\n",ei)
15 printf(" energy input in 1 hour is %ekcal.",eikc);
16 printf("\n coal required is %.3fkg per hour",colreq)
    ;
```

Chapter 8

hydro electric plants

Scilab code Exa 8.1 hydro plant power with parameters of reservoir

```
1 clear
2 clc
3 disp("example 8.1")
4 h=100 //given height
5 q=200 //discharge
6 e=0.9 //efficiency
7 p=(735.5/75)*q*h*e
8 printf("\npower developed by hydro plant is %ekW",p)
```

Scilab code Exa 8.2 STORAGE CAPACITY AND HYDRO GRAPH

```
1 clear
2 clc
3 disp("example 8.2")
```




Figure 8.1: STORAGE CAPACITY AND HYDRO GRAPH

```

4 flow=[0 1000 800 600 400 400 1200 2400 2400 1000 400
      400 1000] //flow in matrix from in the order of
      months
5 y=0:12
6 h=150
7 e=0.85
8 avg=sum(flow)/12
9 printf("\naverage rate of inflow is %dcu-m/sec",avg)
10 p=(735.5/75)*avg*h*e
11 printf("\npower developed is %fkW",p)
12 plot2d2(y,flow)
13
14 xtitle('hydrograph','months','run in cu-m/sec')
15 disp("hydrograph is plotted in figure")
16 for x=1:12
17     t=flow(1,x)
18     a=avg
19     if t<a|t==avg then
20         t=0
21     else
22         t=t-1000
23     end
24     flow1(1,x)=t;
25 end
26 sto=sum(flow1)
27 printf("\nstorage capacity of given plant is %dsec-m
      -month",sto)

```

Scilab code Exa 8.3 STORAGE CAPACITY AND HYDRO GRAPH

```
1 clear
```




Figure 8.2: STORAGE CAPACITY AND HYDRO GRAPH

```

2  clc
3  disp("example 8.3")
4  flow=[1500 1000 500 500 500 1200 2900 2900 1000 400
        600 1600]
5  cod=1000//constant demand
6  plot2d2(flow)
7  xtitle('hydrograph for exp 8.3','months','run off in
        m^3/sec')
8  avg=sum(flow)/12
9  if cod<avg then
10     for x=1:6
11         t=flow(1,x)
12         if t>cod|t==avg then
13
14             t=0
15         else
16             t=cod-t
17         end
18         flow1(1,x)=t;
19     end
20
21     else
22         for x=1:12
23             t=flow(1,x)
24             a=cod
25             if t>a|t==avg then
26                 t=0
27             else
28                 t=t-cod
29             end
30             flow1(1,x)=t;
31         end
32     end
33
34     sto=sum(flow1)
35     printf("storage capacity of plant is %dsec-m-month",
        sto)

```




Figure 8.3: derivation of mass curve

Scilab code Exa 8.4 derivation of mass curve

```

1 clear
2 clc
3 disp("example 8.4")
4 flow=[1500 1000 500 500 500 1200 2900 2900 1000 400
        600 1600]
5 cod=1000//constant demand
6 [m n]=size(flow)
7 mf(1)=1500
8 for i=2:n
9     mf(i)=mf(i-1)+flow(i)

```



```

10 end
11 plot(mf)
12 dd=1:cod:mf(n)
13 avg=sum(flow)/12
14 if cod<avg then
15     for x=1:6
16         t=flow(1,x)
17         if t>cod|t==avg then
18
19             t=0
20         else
21             t=cod-t
22         end
23         flow1(1,x)=t;
24     end
25
26 else
27     for x=1:12
28         t=flow(1,x)
29         a=cod
30         if t>a|t==avg then
31             t=0
32         else
33             t=t-cod
34         end
35         flow1(1,x)=t;
36     end
37 end
38
39 sto=sum(flow1)
40 printf("storage capacity of plant is %dsec-m-month",
        sto)

```




Figure 8.4: HYDRO GRAPH

Scilab code Exa 8.5 HYDRO GRAPH

```
1 clear
2 clc
3 disp("solution of 8.5")
4 flow=[80 50 40 20 0 100 150 200 250 120 100 80]
5 h=100;e=80
6 subplot(211)
7 plot2d2(flow)
8 xtitle('hydrograph','months','run off, millon m3/
    month')
9 fd=gsort(flow)
10 subplot(212)
11 plot2d2(fd)
12 xtitle('flow durement','months','run off')
13
14 t=1:12
15 for x=2:10
16     d=fd(1,x)
17     ad=fd(1,(x-1))
18     if d==ad then
19         t(1,x)=[]
20         t(1,x-1)=t(1,x-1)+1
21         fd(1,x)=[]
22     end
23 end
24 ffw=[fd;t]
25 disp("load duration data is as under")
26 disp(ffw)
27 mf=sum(flow)*106/(30*24*3600)
28 disp("(a)")
29 printf("meanflow is %fm3-sec",mf)
30 disp("(b)")
31 p=(735.5/75)*mf*h*e
```

```
32 printf("power delevered in %dkW=%%.3fMW",p,p/1000)
```

Scilab code Exa 8.6 WATER USED AND LOAD FACTOR OF HYDRO STATION

```
1 clear
2 clc
3 disp("example 8.6")
4 mh=205//mean height
5 a=1000*10^6//in miters
6 r=1.25//annual rain fall
7 er=0.8//efficiency
8 lf=0.75//load factor
9 hl=5//head loss
10 et=0.9//efficiency of turbine
11 eg=0.95//efficiency of generator
12 wu=a*r*er/(365*24*3600)
13 printf("\nwater used is \t\t%f m^3/sec",wu)
14 eh=mh-hl
15 printf("\neffective head is \t%dm",eh)
16 p=(735.5/75)*(wu*eh*et*eg)
17 printf("\npower generated is \t%f kW =\t%f MW",p,p/1000)
18 pl=p/lf
19 printf("\npeak load is \t\t%f Mw \ntherefore the MW
    rating of station is \t%f MW",pl/1000,pl/1000)
20 if eh<=200 then
21 printf("\nfor a head above 200m pelton turbine is
    suitable,\nfrancis turbine is suitable in the
    range of 30m–200m.,\nhowever pelton is most
    suitable")
22 else
23     printf("only pelton turbine is most suitable")
24 end
```


Chapter 9

Nuclear Power stations

Scilab code Exa 9.1 energy equivalent of matter 1 gram

```
1 clear
2 clc
3 disp("example 9.1")
4 m=1*10^-3//mass of 1 grm in kgs
5 c=3*10^8
6 e=m*c^2;
7 E=e/(1000*3600)
8 printf("energy equivalent of 1 gram is %dkWh",E)
```

Scilab code Exa 9.2 mass defect of 1 amu

```
1 clear
2 clc
3 disp("example 9.2")
4 amu=1.66*10^-27//mass equivalent in kgs
```

```

5 c=3*10^8
6 j=6.242*10^12
7 e=amu*c^2
8 E=e*j;
9 printf("energy evalent in joules is %ejoules \n
        energy equivalent in Mev is %dMeV \n hense shown",
        e,E)

```

Scilab code Exa 9.3 binding energy of ${}_{28}^{92}\text{Ni}$

```

1 clear
2 clc
3 disp("example 9.3")
4 hm=2.0141
5 hp=1.007825
6 hn=1.008665
7 nm=58.9342
8 np=28
9 nn=59
10 um=235.0439
11 up=92
12 un=235
13 hmd=hp+hn-hm;nmd=np*hp+(nn-np)*hn-nm;umd=up*hp+(un-
    up)*hn-um;
14 hbe=931*hmd;nbe=931*nmd;ube=931*umd;
15 ahbe=hbe/2;anbe=nbe/nn;aube=ube/un;
16 printf("\t(a)\n mass defect is for hydrogen %famu \n
        total binding energy for hydrogens %fMev \n
        average binding energy for hydrogen is %fMeV",hmd
        ,hbe , ahbe)
17 printf("\n\t(b)\n mass defect is for nickel %famu \n
        total binding energy for nickel is %fMev \n
        average binding energy for nickelis %fMeV",nmd,

```

```

nbe , anbe)
18 printf("\n\t(c)\n mass defect of uranium is %famu \n
total binding energy uranium is %fMev \n average
binding energy uranium is %fMeV", umd, ube, aube)

```

Scilab code Exa 9.4 half life of uranium

```

1 clear
2 clc
3 disp("example 9.4")
4 no=1.7*10^24
5 hl=7.1*10^8
6 t=10*10^8
7 lm=0.693/(hl)
8 lmda=lm/(8760*3600)
9 ia=lmda*no
10 n=no*(exp(-lm*t))
11 printf("(lamda) disintegrations per sec is %ebq \n
initial activity is lamda*na is %ebq \n final
number of atoms is %eatoms", lmda, ia, n)

```

Scilab code Exa 9.5 power produced by fissioning 5 grams of uranium

```

1 clear
2 clc
3 disp("example 9.5")
4 um=5
5 owp=2.6784*10^15
6 an=6.023*10^23

```



```

7 na1g=an/235
8 na5g=an*5/235
9 p=na5g/owp
10 printf("1 watt power requvires %efussions per day \n
        number of atoms in 5 gram is %eatoms \n power is
        %eMW ",owp,na5g,p)

```

Scilab code Exa 9.6 fuel requirement for given energy

```

1 clear
2 clc
3 disp("example 9.6")
4 pp=235
5 pe=0.33
6 lf=1
7 teo=pp*8760*3600*10^6
8 ei=teo/pe
9 nfr=3.1*10^10 //fessions required
10 tnfr=nfr*ei
11 t1gu=2.563*10^21 //total uranium atoms in 1 gram
12 fure=tnfr/t1gu
13 printf("total energy input %eWatt sec \n energy
        input is %eWatt-sec\n total number of fissions
        required is %efissions \n fuel required is %e
        grams %dkg",teo,ei,tnfr,fure,fure/1000)

```

Scilab code Exa 9.7 number of collisions for energy change

```

1 clear

```

```
2 clc
3 disp("example 9.7")
4 en=3*106
5 a=12
6 fen=0.1
7 Es=2/(12+2/3)
8 re=exp(Es)
9 printf("(a)\nratio of energies per collision is %f",
    re)
10 rietf=en/fen
11 ldie=log(rietf)
12 nc=ldie/Es
13 printf("(b)\nratio of iniial to final energies is %e
    \n logarithemic decrement in energy is %f \n
    number of collisions is %d",rietf,ldie,nc)
```

Chapter 10

ECONOMIC OPERATION OF STEAM PLANTS

Scilab code Exa 10.1 SHARING OF LOAD BETWEEN STATIONS

```
1 clear
2 clc
3 disp("example 10.1")
4 mp=250 //maximum power
5 function [ic]=unit1(p1) //ic equation of unit 1
6     ic=0.2*p1+30
7 endfunction
8 function [ic]=unit2(p2)//ic equation of unit 2
9     ic=0.15*p2+40
10 endfunction
11 mil=20//minimum load
12 disp("minimum load ic is")
13 ic=[unit1(mil),unit2(mil)]
14 [m,n]=max(ic)
15 if m==unit2(mil) then
16     for x=20:100
17         if m==unit1(x) then
18             break
19             end
```

```

20     end
21     printf("ic of unit1 =ic of unit2 when unit2=%dMW
           and unit1=%dMW",mil,x)
22 end
23 function [p1,p2]=un(ic)
24     p1=(ic-30)/0.2
25     p2=(ic-40)/0.15
26 endfunction
27 printf("load division \n")
28 me=ceil(unit2(mil)/10)
29 for x=me*10:5:100
30     ii=0
31     [m,n]=un(x)
32     if m>=mp|n>=mp then
33         if n>mp then
34             p=2
35         end
36         if m>mp then
37             p=1
38         end
39         for y=x-5:0.5:x
40             [c,v]=un(y)
41             m1=[c,v]
42             if mp==m1(p) then
43                 ii=1
44                 break
45             end
46         end
47         [pp qq]=un(y)
48         printf("\n for plant ic %3.1fMW \tthen p1=%dMW\t
           p2 =%dMW",unit1(pp),pp,qq)
49         ii=1
50         break
51     end
52 if ii==0 then
53     l=m+n
54     printf("\n for plant ic %dMW \tthen p1 is
           %dMW\t plant2 is %dMW and total is %dMW ",

```

```

        x,m,n,l)
55     end
56 end
57 a=unit1(mp);b=unit2(mp)
58 printf("\n for plant ic %dMW \t then p1 is %dMW\t
        plant2 is %dMW and total is %dMW ",a,mp,mp,2*mp)

```

Scilab code Exa 10.2 COST ON DIFFERENT STATIONS ON INCREMENTAL COST METHOD

```

1  clear
2  clc
3  disp("example 10.2")
4  mp=250 //from example 10.1
5  function [ic]=unit1(p1)
6      ic=0.2*p1+30
7  endfunction
8  function [ic]=unit2(p2)
9      ic=0.15*p2+40
10 endfunction
11 mil=20
12 ttt=225
13 function [p1,p2]=un(ic)
14     p1=(ic-30)/0.2
15     p2=(ic-40)/0.15
16 endfunction
17 for x=40:5:60
18     [e,r]=un(x)
19     if ttt==e+r then
20         printf("for the same incremental costs unit1
                should supply %dMW and unit 2 should
                supply %dMW,for equal sharing each unit
                should supply %3.1fMW",e,r,ttt/2)
21         break

```

```

22     end
23 end
24 opo=ttt/2
25 u1=integrate('unit1','p1',opo,e)
26 u2=integrate('unit2','p2',r,opo)
27 uuu=(u1+u2)*8760
28 printf("\nyearly extra cost is (%3.2f-%3.2f)8760 =
        %dper year",u1,u2,uuu)
29 printf("\nthis if the load is equally shared by the
        two units an extra cost of Rs.%d will be incurred
        .in other words economic loading would result in
        saving of Rs.%dper year",uuu,uuu)

```

Scilab code Exa 10.3 SHARING OF LOAD BETWEEN STATIONS WITH PARTICIPATION FACTOR

```

1 clear
2 clc
3 disp("example 10.3")
4 function [ic]=unit1(p1)
5     ic=0.2*p1+30
6 endfunction
7 function [ic]=unit2(p2)
8     ic=0.15*p2+40
9 endfunction
10 tol=400
11 pd=50
12 u1c=5
13 u2c=1/0.15//from example10_1
14 p1pd=u1c/(u1c+u2c)
15 p2pd=u2c/(u1c+u2c)
16 pi=p1pd*pd
17 pt=p2pd*pd
18 printf("p1=%1.5fMW\n p2=%1.5fMW",pi,pt)

```

```

19 p11=pi+tol/2
20 p22=pt+tol/2
21 up1=unit1(p11)
22 up2=unit2(p22)
23 printf("\nthe total load on 2 units would be %3.2
    fMW and %3.2fMW respectevily. it is easy to
    check that incremental cost will be same for two
    units at these loading.\n incremental cost of
    unit1 is %3.2fRs.MW,\n incremantal cost of unit
    2 is %3.2 fRs./MW",p11 ,p22 ,up1 ,up2)

```

Scilab code Exa 10.5 LOSS COEFFICIENTS AND TRANSMISSION LOSS

```

1 clear
2 clc
3 disp(" example10.5")
4 i1=0.8
5 i2=1.0
6 l1=complex(0.04,0.12)
7 l2=complex(0.03,0.1)
8 l3=complex(0.03,0.12)
9 v1=1
10
11 i3=i1+i2
12 v1=v1+i3*(l1)+i1*(l2)
13 v2=v1+i3*(l1)+i2*(l3)
14 p1=real(i1*v1)
15 p2=real(i2*v2)
16 cos1=real(v1)/abs(v1)
17 cos2=real(v2)/abs(v2)
18 b11=abs((real(l1)+real(l2))/(v1^2*cos1^2))
19 b22=abs((real(l1)+real(l3))/(v2^2*cos2^2))
20 b12=abs((real(l1))/(v1*v2*cos1*cos2))

```

```

21 p1=(p1^2)*b11+(p2^2)*b22+2*p1*p2*b12
22 printf(" i1+i3=%dpu\nv1=%1.3 f+%1.3 fp . u\nv2=%1.3 f+%1.3
    fp . u\np1=%1.3 fp . u\np2=%1.3 fp . u\ncos (ph1)=%1.3 f\
    ncos (ph2)=%1.3 f\nb11=%1.5 fp . u\nb22=%1.5 fp . u\nb12=
    %1.5 fp . u\npl=%1.6 fp . u", i3, v1, imag(v1), v2, imag(v2)
    , p1, p2, cos1, cos2, b11, b22, b12, p1)

```

Scilab code Exa 10.7 LOSS COEFFICIENTS AND TRANSMISSION LOSS

```

1 clear
2 clc
3 disp(" example10.7")
4 za=complex(0.03,0.09)
5 zb=complex(0.1,0.3)
6 zc=complex(0.03,0.09)
7 zd=complex(0.04,0.12)
8 ze=complex(0.04,0.12)
9 ia=complex(1.5,-0.4)
10 ib=complex(0.5,-0.2)
11 ic=complex(1,-0.1)
12 id=complex(1,-0.2)
13 ie=complex(1.5,-0.3)
14 il1=.4
15 il2=.6
16 na1=1;nb1=0.6;nc1=0;nd1=.4;ne1=.6
17 na2=0;nb2=-0.4;nc2=1;nd2=.4;ne2=.6
18 v1=1
19 //some thing is messed
20 v1=v1+za*ia
21 v2=v1-zb*ib+zc*ic
22 a1=atan(imag(ia)/real(ia))
23 a2=atan(imag(ic)/real(ic))
24 cosa=cos(a1-a2)

```



```

25 cosph1=cos(atan(imag(v1)/real(v1))-a1)
26 cosph2=cos(atan(imag(v2)/real(v2))-a2)
27 b11=(na1^2*real(za)+nb1^2*real(zb)+nc1^2*real(zc)+
      nd1^2*real(zd)+ne1^2*real(ze))/(abs(v1)^2*cosph1)
28 b22=(na2^2*real(za)+nb2^2*real(zb)+nc2^2*real(zc)+
      nd2^2*real(zd)+ne2^2*real(ze))/((abs(v2)^2)*
      cosph2)
29 bb12=(abs(v1)*abs(v2)*cosph1*cosph2)
30 ab12=(na2*na1*real(za)+nb2*nb1*real(zb)+nc1*nc2*real
      (zc)+nd2*nd1*real(zd)+ne2*ne1*0.03)
31 b12=cosa*ab12/bb12
32 printf("bus voltages at 2 buses are \nv1=%1.3f+i%1.3
      f,\nv2=%1.3f+i%1.3f",real(v1),imag(v1),real(v2),
      imag(v2))
33 printf("\nloss coffecients are \nb11=%1.5fp.u\nb22=
      %1.5fp.u\nb12=%1.5fp.u\n",b11,b22,b12)
34 printf("loss coffecients in actual values is \nb11=
      %eM(W)-1\nb22=%eM(W)-1\nb12=%eM(W)-1\n",b11/100,
      b22/100,b12/100)

```

Scilab code Exa 10.8 SHARING OF LOAD BETWEEN STATIONS WITH PARTICIPATION FACTOR

```

1 clear
2 clc
3 disp("example 10.8")
4 r1=22;r2=30;q1=0.2;q2=0.15
5 b22=0;b12=0;p1=100;p1=15//transmission losses are 0
6 b11=p1/(p1)^2
7 function [p1,p2]=power(x) //mathematical computation
8     p1=(x-r1)/(q1+2*b11*x)
9     p2=(x-r2)/q2
10 endfunction
11 [a,b]=power(60)

```

```

12 printf(" l1=1/(1-%.3f*p1)\n l2=[1/(1-0)]=1\n given
    lamda=60\n since ic1*l1=lamda ; ic2*l2=lamda\n total
    load=%dMW", b11*2, a+b-(b11*a^2))

```

Scilab code Exa 10.9 COST CONDITIONS WITH CHANGE IN LOAD ON PLANT

```

1 clear
2 clc
3 disp(" example 10.9")
4 r1=22; r2=30; q1=0.2; q2=0.15
5 b22=0; b12=0; p1=100; p1=15 // transmission losses are 0
6 b11=p1/(p1)^2
7 function [p1,p2]=power(x) // mathematical computation
8     p1=(x-r1)/(q1+2*b11*x)
9     p2=(x-r2)/q2
10 endfunction
11 [a,b]=power(60)
12 pt=a+b-(b11*a^2)
13
14
15
16
17 z=integrate('q1*u+r1', 'u', a, 161.80)
18 y=integrate('q2*v+r2', 'v', b, 162.5)
19 m=z+y
20 printf(" net change in cost =Rs.%dper hour", m)
21 printf(" \n thus scheduling the generation by taking
    transmission losses into account would mean a
    saving of Rs.%dper hour in fuel cost", m)

```

Scilab code Exa 10.10 SHARING OF LOAD BETWEEN STATIONS WITH ITERATION METHOD

```
1 clear
2 clc
3 disp("example 10.10")
4 b11=0.001
5 b12=-0.0005
6 b22=0.0024
7 q1=0.08
8 r1=16
9 q2=0.08
10 r2=12
11 lamda=20
12
13 p2=0
14 for x=1:4
15     p1=(1-(r1/lamda)-(2*p2*b12))/((q1/lamda)+2*b11)
16
17     p2=(1-(r2/lamda)-(2*p1*b12))/((q2/lamda)+2*b22)
18
19 end
20 p1=b11*p1^2+2*b12*p1*p2+b22*p2^2
21 pr=p1+p2-p1
22 printf("thus \t p1=%2.1fMW, p2=%2.1fMW\n p1=%1.1fMW\n
        npower resevied %2.1fMW", p1, p2, p1, pr)
```

Scilab code Exa 10.11 COST CHARACTERISTIC UNDER COMBAINED STATIONS CONDITION

```

1 clear
2 clc
3 disp("example 10.11")
4 a1=561;b1=7.92;c1=0.001562
5 a2=310;b2=7.85;c2=0.00194
6 ce=c1*c2/(c1+c2)
7 printf("\nce=%e",ce)
8 be=((b1/c1)+(b2/c2))*ce
9 printf("\nbe=%1.4f",be)
10 ae=a1-((b1^2)/4*c1)+a2-((b2^2)/4*c2)+((be^2)/4*ce)
11 printf("ae=%3.3f \n cost characteristics of
    composite unit for demand pt is \n ct=%3.3f+%1.4f
    *p1+%ep1^2",ae,ae,be,ce)

```

Scilab code Exa 10.12 SHARING OF LOAD BETWEEN STATIONS

```

1 clear
2 clc
3 disp("example 10.12")
4 a1=7700;b1=52.8;c1=5.5*10^-3
5 a2=2500;b2=15;c2=0.05//given equition
6 plo=200;pup=800
7 ct=1000
8 l=[500,900,1200,500];t=[6 16 20 24]//from given
    graph
9 function [p1,p2]=cost(y)
10     p1=(2*c2*y-(b1-b2))/(2*(c1+c2))
11     p2=y-p1
12 endfunction
13 ma=max(l)
14 mi=min(l)
15 for x=1:3
16     [e g]=cost(l(x))

```

```

17     if e<plo|g<plo|e>pup|g>pup then
18         if e<plo|g<plo then
19             [v,u]=min(e,g)
20             if u==1 then
21                 e=plo
22                 g=l(x)-e
23             else
24                 g=plo
25                 e=l(x)-g
26             end
27         end
28
29     end
30     printf("\np1=%3.2fMW\tp2=%3.2fMW",e,g)
31     end

```

Scilab code Exa 10.13 ECONOMIC SCHEDULING BETWEEN POWER STATION

```

1  clc
2  clear
3  disp("example 10 13")
4  a1=2000;b1=20;c1=0.05;p1=350;p2=550
5  a2=2750;b2=26;c2=0.03091
6  function [co]=cost(a,b,c,p)
7      co=a+b*p+c*p^2
8  endfunction
9  disp("(a)")
10 toco=cost(a1,b1,c1,p1)+cost(a2,b2,c2,p2)
11 printf("total cost when each system supplies its own
        load Rs%.3f per hour",toco)
12 l=p1+p2
13 p11=(b2-b1+2*c2*l)/(2*(c1+c2))
14 p22=l-p11

```

```

15 totco=cost(a1,b1,c1,p11)+cost(a2,b2,c2,p22)
16 sav=toco-totco
17 tilo=p11-p1
18 disp("(b)")
19 printf("\n total cost when load is supplied in
        economic load dispatch method Rs%d per hour \n
        saving %.3f \n tie line load %.3f MW",totco,sav,
        tilo)

```

Scilab code Exa 10.14 ECONOMIC SCHEDULING BETWEEN POWER STATION

```

1 clear
2 clc
3 disp(" example10.14")
4 a1=5000;b1=450;c1=0.5;//for system 1
5 e1=0.02;e2=-0.02//error
6 a1c=a1*(1-e1);b1c=b1*(1-e1);c1c=c1*(1-e1)
7 a2c=a1*(1-e2);b2c=b1*(1-e2);c2c=c1*(1-e2)
8 t1=200
9 function [co]=cost(a,b,c,p)
10     co=a+b*p+c*p^2
11 endfunction
12 p11=(b2c-b1c+2*c2c*t1)/(2*(c1c+c2c))
13 p22=t1-p11
14 totco=cost(a1c,b1c,c1c,p11)+cost(a2c,b2c,c2c,p22)
15 printf("\n power at station 1 is %dMW \t power at
        station 2 is %dMW \n total cost on economic
        critieria method Rs%d per hour",p11,p22,totco)
16 tocoe=cost(a1c,b1c,c1c,t1/2)+cost(a2c,b2c,c2c,t1/2)
17 eop=tocoe-totco
18 printf("\n extra operating cost due to erroneous
        scheduling Rs.%d per hour",eop)

```

Scilab code Exa 10.15 ECONOMIC SCHEDULING BETWEEN POWER STATION

```
1  clc
2  clear
3  disp("example 10_15")
4  c1=0.002;b1=0.86;a1=20
5  c2=0.004;b2=1.08;a2=20
6  c3=0.0028;b3=0.64;a3=36
7  fc=500
8  maxl=120
9  minl=36
10 t1=200
11 d=[1 1 1;2*fc*c1 -fc*2*c2 0;0 -fc*2*c2 fc*2*c3]
12 p=[t1;fc*(b2-b1);fc*(b2-b3)]
13 pp=inv(d)*p //matrix inversion method
14 printf("\nloads on generaating station by economic
        creatirian method is %dMW,%dMW,%dMW",pp(1),pp(2),
        pp(3))
15 for i=1:3
16     if pp(i)<minl then
17         pp(i)=minl
18         printf("\nload on generating station %d is
                less then minimum value %dMW \n so it is
                made equal to minimum value %dMW",i,minl,
                minl)
19         e=[1 1;d(2,1) -d(3,3)]
20         q=[(t1-pp(i));-p(i)]
21         qq=inv(e)*q //matrix inversion method
22 printf("\nloads on generaating station by economic
        creatirian method is %.3fMW,%.3fMW",qq(1),qq(2))
23     end
24     if pp(i)>maxl then
```

```

25         pp(i)=max1
26         printf("\nload on generating station %d is
                greater than maximum value %dMW \n so it
                is made equal to mmaximum value %dMW",i,
                max1,max1)
27         e=[1 1;d(2,1) -d(3,3)]
28         q=[(t1-pp(i));-p(i)]
29         qq=inv(e)*q //matrix inversion method
30 printf("\nloads on generaating station by economic
        creatirian method is %.2fMW,%.2fMW",qq(1),qq(2))
31     end
32 end

```

Scilab code Exa 10.16 COMPARITION BETWEEN UNIFORM LOAD AND DISTRUBTED LOAD

```

1  clc
2  clear
3  disp(" example 10.16")
4  //given
5  ia=32;ib=32;ic=1.68;f=10^5
6  wt=18;rt=24-wt
7  p=30
8  function [in]=inpu(a,b,c,f,t,p)
9      in=(a+b*p+c*p^2)*f*t
10 endfunction
11 hi1=inpu(ia,ib,ic,f,wt,p);hi2=inpu(ia,ib,ic,f,rt,p
    /2)
12 disp("(a)")
13 printf("for full load condition for %d hours is %ekj
        \n for half load condition for%d s %ekj \n total
        load %ekj",wt,hi1,rt,hi2,hi1+hi2)
14 disp("(b)")
15 te=p*wt+(p/2)*rt

```



```

16 ul=te/24
17 hin=inpu(ia,ib,ic,f,24,ul)
18 sav=hi1+hi2-hin
19 savp=sav/(te*1000)
20 printf("\n total energy produced\t%dMW \n unifor
    load\t%dMW \n heat input under uniform load
    condition %ekj \n saving in heat energy %ekj \n
    saving in heat energy per kWh %dkj/kWh",te,ul,hin
    ,sav,savp)

```

Scilab code Exa 10.17 ECONOMIC SCHEDULING BETWEEN POWER STATION

```

1 clc
2 clear
3 disp("example 10.17")
4 //given
5 a1=450;b1=6.5;c1=0.0013
6 a2=300;b2=7.8;c2=0.0019
7 a3=80;b3=8.1;c3=0.005
8 t1=800//total load
9 ma(1)=600
10 mi(1)=100
11 ma(2)=400
12 mi(2)=50
13 ma(3)=200
14 mi(3)=50
15 d=[1 1 1;2*c1 -2*c2 0;0 -2*c2 2*c3]
16 p=[t1;(b2-b1);(b2-b3)]
17 pp=inv(d)*p //matrix inversion method
18 printf("\nloads on generaating station by economic
    creatirian method isp1=%fMW,p2=%fMW,p3=%fMW",pp
    (1),pp(2),pp(3))
19 for i=1:3

```

```
20     if pp(i)<mi(i) then
21         pp(i)=mi(i)
22     end
23     if pp(i)>ma(i) then
24         pp(i)=ma(i)
25     end
26 end
27 pp(2)=t1-pp(1)-pp(3)
28 printf("\nloads on generating station under critical
        conditions p1=%dMW p2=%dMW p3=%dMW",pp(1),pp(2),
        pp(3))
```

Chapter 11

HYDRO THERMAL CO ORDINATION

Scilab code Exa 11.1 SCHEDULING OF POWER PLANT

```
1  clc
2  clear
3  disp("example 11 1")
4  wd=[0 5 8 12 13 17 21 24] //given week days
5  wlld=[100 150 250 100 250 350 150] //given load in
   week days
6  wld=[wlld 0]
7  we=[0 5 17 21 24] //given week ends
8  wed=[100 150 200 150] //given load in week ends
9  wed=[wed 0]
10 h=90 //head
11 f=50 //flow
12 et=0.97 //is available for 97 percent
13 eff=0.9 //efficiency
14 t1=0.05 //transmission loss
15 pa=735.5*f*h*eff/75 //power available
16 nap=pa*(1-t1) //net available power
```




Figure 11.1: SCHEDULING OF POWER PLANT

```

17 he=nap*24/1000 //hydro energy for 24 in MW
18 he1=round(he/100)*100
19 [m,n]=size(wd)
20 [x,y]=min(wlld)
21 [q,r]=max(wlld)
22 for i=1:n-1
23     fl(i)=wd(i+1)-wd(i)
24 end
25 [o,p]=size(we)
26 for i=1:p-1
27     fl1(i)=we(i+1)-we(i)
28 end
29 for j=x:10:q
30     pp=wlld-j
31     for l=1:n-1
32         if pp(l)<0 then
33             pp(l)=0
34         end
35     end
36     heq=pp*fl
37     heq=round(heq/100)*100
38     if heq==he1 then
39         break
40     end
41 end//rearrangeing for plot
42 subplot(211)
43 plot2d2(wd,wld)
44 xtitle("chronological load curve for week day for
         example 11.1","hour of day","load MW")
45 subplot(212)
46 plot2d2(we,wed)
47 xtitle("chronological load curve for weekend day for
         example 11.1","hour of day","load MW")
48
49 printf("power available from the hydro plant for
         %dMW of the time is %.2fMW",et*100,pa/1000)
50 printf("\nnet available hydra power after taking
         transmission loss into account %.2fMW",nap/100)

```

```

51 printf("\nhydro energy available during 24 hours %.2
    fMW",he)
52 printf("\nthe magnitude of hydro power is %dMW \
    ntotal capacity of hydro plant required on week
    days %dMW ",q-j,(q-j)/(1-t1))
53 printf("capacity of thermal plant on week days %dMW"
    ,q)
54 printf("\nthe schedule for hydro plant is on week
    days")
55 for i=1:n
56     if wd(i)>12 then
57         wd(i)=wd(i)-12
58     end
59 end
60 disp(wd)
61 disp(round(pp/(1-t1)))
62 disp("the schedule for thermal plant is on week days
    ")
63 disp(wd)
64 disp(wlld-pp)
65 [m,n]=size(we)
66 [x,y]=min(wed)
67 [q,r]=max(wed)
68 for j=x:10:q
69     pp=wed-j
70     for l=1:n-1
71         if pp(l)<0 then
72             pp(l)=0
73         end
74     end
75 pp(n)=[]
76     heq=pp*f11
77     heq=floor(heq/100)*100
78     if heq==he1 then
79         break
80     end
81 end
82 printf("\nthe magnitude of hydro power is %dMW \

```

```

        ntotal capacity of hydro plant required on week
        ends %dMW ",q-j,(q-j)/(1-t1))
83 printf("capacity of thermal plant on week ends %dMW"
        ,q)
84 printf("\nthe schedule for hydro plant is on week
        ends")
85 for i=1:n
86     if we(i)>12 then
87         we(i)=we(i)-12
88     end
89 end
90 disp(we)
91 disp(round(pp/(1-t1)))
92 disp("the schedule for thermal plant is on week days
        ")
93 disp(we)
94 pp(n)=0
95 disp(wed-pp)

```

Scilab code Exa 11.2 generation schedule and daily water usage of power plant

```

1  clc
2  clear
3  disp("example 11.2")
4  //given
5  l1=700;t1=14;l2=500;t2=10
6  ac=24;bc=0.02//variables of cost equation
7  aw=6;bw=0.0025 //variables of watere quantity
   equation
8  b22=0.0005 //loss coefficient
9  r2=2.5
10 lam=1:0.001:40
11 gg=1;q=1

```

```

12 for lam=25:0.001:40
13     a=[2*bc 0;0 r2*bw*2+2*b22*lam]
14     b=[lam-ac;lam-aw*r2]
15     p=inv(a)*b
16     g=round(p(1)+p(2))
17     l=round(l1+b22*p(2)^2)
18     lq=round(l2+b22*p(2)^2)
19     if g>=l then
20         printf("\nfor load condition %dMW \n then, \
n \t lamda %f \t p1=%dMW \n \t p2=%dMW \t
p1=%dMW" ,l1,lam,p(1),p(2),2*b22*p(2))
21         break
22     end
23 end
24 for lam=25:0.001:40
25     a=[2*bc 0;0 r2*bw*2+2*b22*lam]
26     b=[lam-ac;lam-aw*r2]
27     pq=inv(a)*b
28     g=round(pq(1)+pq(2))
29     lq=round(l2+b22*pq(2)^2)
30
31     if g>=lq then
32         printf("\nfor load condition %dMW \n then, \
n \t lamda %f \t p1=%dMW \n \t p2=%dMW \t
p1=%dMW" ,l2,lam,pq(1),pq(2),2*b22*pq(2))
33         break
34     end
35 end
36 dwu=[(aw+bw*p(2))*p(2)*t1+t2*(aw+bw*pq(2))*pq(2)
] *3600
37 doc=[(ac+bc*p(1))*p(1)*t1+(ac+bc*pq(1))*pq(1)*t2]
38 printf("\ndaily water used %fm^3 \ndaily operating
cost of thermal plant Rs%f",dwu,doc)

```

Scilab code Exa 11.3 water usage and cost of water by hydro power plant

```
1  clc
2  clear
3  disp("example 11.3")
4  //given
5  p=250//load
6  rt=14 //run time
7  t=24//total time
8  ac=5;bc=8;cc=0.05 //variables of cost equation
9  bw=30;cw=0.05 //variables of water per power
10 qw=500//quantity of water
11 lam=bc+cc*2*p //lambda
12 a=-qw*(10^6)/(3600*rt)
13 inn=sqrt(bw^2-4*cw*a)
14 phh1=(-bw+inn)/(2*cw)//solution of quadratic
    equation
15 phh2=(-bw-inn)/(2*cw)
16 if phh1>0 then
17     r=lam/(bw+cw*phh1)
18     printf(" hydro plant power is %dMW \n the cost
        of water is %fRs.per hour/m^3/sec",phh1,r)
19 end
20 if phh2>0 then
21     r=lam/(bw+cw*phh2)
22     printf(" hydro plant power is %dMW \n the cost
        of water is %fRs.per hour/m^3/sec",phh2,r)
23 end
```

Chapter 12

parallel operation of alternators

Scilab code Exa 12.1 load sharing between alternators

```
1  clc
2  clear
3  disp('example 12 1')
4  p=4000 //given kva of alternator
5  fn1=50 //frequency on no load
6  f1=47.5 //frequency on load
7  fn2=50 //frequency on no load on second alternator
8  f2=48 //frequency on load on second alternator
9  l=6000 //load given two to alternator
10 df1=fn1-f1 //change in 1 alternator frequency
11 df2=fn2-f2 //change in 2 alternator frequency
12 l1=df2*(l)/(df2+df1) //load on 1 alternator
13 disp('a')
14 l2=l-l1
15 printf(" load on 1 alternator %.2fkW \n load on 2
        alternator %.2fkW",l1,l2)
16 m1=df2*p/df1 //load on 1 machine when machine 2
        on full load
17 l1=m1+p
```

```

18 disp('b')
19 printf(" load supplied by machine 1 with full load
    on machine2 %dkW \n total load is %dkW",m11,l1)

```

Scilab code Exa 12.2 different parameters between parallel operation of generator

```

1 clc
2 clear
3 disp('example12_2')
4 l1=3000 //load on 1 machine
5 pf1=0.8 //pf on 1 machine
6 i2=150 //current on 2 machine
7 z1=0.4+12*i //synchronour impedance
8 z2=0.5+10*i
9 vt=6.6 //terminal voltage
10 al=l1/2 //active load on each machine
11 cosdb=al/(vt*i2*sqrt(3)) //cos db
12 db=acosd(cosdb) //angle in digree
13 ib=i2*complex(cosdb,-sind(db)) //current in complex
    number
14 it=l1/(vt*pf1*sqrt(3)) //total current
15 itc=complex(it*pf1,-it*sind(acosd(pf1))) //total
    current in complex
16 ia=itc-ib
17 pfa=atan(imag(ia)/real(ia)) //pf of current a
18 ea=(vt/sqrt(3))+ia*(z1)/1000 //voltage a
19 pha=atand(imag(ea)/real(ea)) //phase angle of unit
    a
20 printf("induced emf of a machine a %.2 f+%.2 fi =%fkV
    per phase",real(ea),imag(ea),abs(ea))
21 eb=(vt/sqrt(3))+ib*(z2)/1000 //voltage b
22 phb=atand(imag(eb)/real(eb)) //phase angle of unit
    b

```

```
23 printf("\ninduced emf of a machine b %.2f+%.2fi =
    %fkV per phase",real(eb),imag(eb),abs(eb))
```

Scilab code Exa 12.3 circulating current between parallel generators

```
1 clc
2 clear
3 disp('example12_3')
4 e1=3000;ph1=20;e2=2900;ph2=0; //given induced emf of
    two machines
5 z1=2+20*i;z2=2.5+30*i //impedence of two
    synchronous machine
6 z1=10+4*i //load impedance
7 e11=e1*(cosd(ph1)+sind(ph1)*i)
8 e22=e2*(cosd(ph2)+sind(ph2)*i)
9 is=(e11-e22)*z1/(z1*z2+(z1+z2)*z1)
10 printf("current is %.2f%.2fiA =%.2fA",real(is),imag(
    is),abs(is))
```

Scilab code Exa 12.4 different parameters between parallel operation of generator

```
1 clc
2 clear
3 disp('example 12 4')
4 z=10+5*i //load
5 e1=250;e2=250 //emf of generator
6 z1=2*i;z2=2*i //synchronous impedance
```

```

7 v=(e1*z2+z1*e2)/((z1*z2/z)+z1+z2);vph=atand(imag(v)/
  real(v)) //substitution the value in equation
  12.10
8 i1=(z2*e1+(e1-e2)*z)/(z1*z2+(z1+z2)*z);iph=atand(
  imag(i1)/real(i1)) //substitution the value in
  equation 12.7
9 pf1=cosd(vph-iph)
10 pd=v*i1*pf1
11 printf("terminal voltage %.2fV \ncurrent supplied by
  each %.2fA \npower factor of each %.3f lagging \
  npower delivered by each %.4fKW",abs(v),abs(i1),
  abs(pf1),abs(pd))

```

Scilab code Exa 12.5 synchronising power per mechanical degree of angular displacement

```

1 clc
2 clear
3 disp('example 12 5')
4 po=5 //mva rating
5 v=10 //voltage in kv
6 n=1500;ns=n/60 //speed
7 f=50 //frequency
8 pfb=0.8//power factor in b
9 x=0.2*i //reactance of machine
10 md=0.5 //mechanical displacement
11 //no load
12 v=1;e=1;
13 p=4
14 spu=v*e/abs(x);sp=spu*po*1000;mt=(%pi*p)/(180*2)
15 spm=sp*mt //synchronous power in per mech.deree
16 st=spm*md*1000/(2*ns*%pi)
17 disp('(a)')
18 printf(" synchronous power %dkW \n synchronous

```

```

    torque for %.1f displacement %dN-M', spm, md, st)
19 disp('(b) full load')
20 ee=e+x*(pfb-sind(acosd(pfb))*%i)
21 spb=v*abs(ee)*cosd(atan2(imag(ee)/real(ee)))/abs(x)
    //synchronous power
22 sppm=spb*po*1000*mt //synchronous power per mech.
    degree
23 stp=sppm*md*1000/(2*pi*ns) //synchronous torque
    under load
24 printf(" synchronous power %dkW \n synchronous
    torque for %.1f displacement %dN-M', sppm, md, stp)

```

Scilab code Exa 12.6 synchronising power per mechanical degree of angular displacement

```

1 clc
2 clear
3 disp('example 12 6')
4 po=2*10^6; p=8; n=750; v=6000; x=6*%i; pf=0.8; //given
5 i=po/(v*sqrt(3))
6 e=(v/sqrt(3))+i*x*(pf-sind(acosd(pf))*%i)
7 mt=p*pi/(2*180)
8 cs=cosd(atan2(imag(e)/real(e)))
9 ps=abs(e)*v*sqrt(3)*cs*mt/(1000*abs(x))
10 ns=n/60
11 ts=ps*1000/(2*pi*ns)
12 printf(" synchronous power %.1fkW per mech.degree \n
    synchronous torque %dN-m", ps, ts)

```

Scilab code Exa 12.7 load parameters between alternators

```

1  clc
2  clear
3  disp('example 12 7')
4  i=100;pf=-0.8;v=11*1000;x=4*%i;ds=10;pf=-0.8 //
    given , currents , power factor , voltage , reactance ,
    delta w.r.t steem supply , pf of alternator
5  e=(v/sqrt(3))+(i*x*(pf-sind(acosd(pf))*%i))
6  disp('a')
7  ph=atand(imag(e)/real(e))
8  printf(" open circuit emf %dvolts per phase and %.2 f
    degree" ,abs(e),ph)
9  d=ds-ph
10 eee=round(abs(e)/100)*100
11 ic=round(abs(eee)*sind(d)/abs(x))
12 iis=(eee^2-(abs(x)*ic)^2)^(0.5)
13 is=(iis-v/sqrt(3))/abs(x)
14 tad=is/ic
15 d=atand(tad)
16 ii=ic/cosd(d)
17 pff=cosd(d)
18 disp('b. ')
19 printf(" current %.1fA \n power factor %.3 f" ,ii,pff)
20 disp('c. ')
21 ia=ii*pff/abs(pf)
22 printf(" current %.2fA" ,ia)

```

Chapter 13

MAJOR ELECTRICAL EQUIPMENT IN POWER PLANTS

Scilab code Exa 13.1 fault current with different generators

```
1 clc
2 clear
3 disp('example 13.1')
4 pg=3000 //kva rating of generators single phase
5 xg=0.1 //10%reactanse of generator
6 vg=11 //voltage at the terminals of generator
7 xbf=5 //reactanse of feeder fron bus to fault
8 pb=pg;vb=vg;ib=pg/vg //let power and voltage of as
   respective base then current base
9 zb=(vb*10^3)/ib //base impedance
10 xpu=xbf/zb //per unit reactance of feeder
11 tx=(xg/2)+(xpu) //total reactance
12 sckva=pg/tx //short circuit kva is ratio ofpower to
   total reactance
13 sci=sckva/vg //short circuit current
14 disp('a')
15 printf(" p.u.feeder reactor %.3fp.u \n total
```



```

    reactance is %.3fp.u \n short circuit kVA %dkVA \
    n short circuit current %.1fA",xpu,tx,sckva,sci)
16 gz=zb*xg //generator impedance
17 tz=(gz/2)+xbf //total impedance
18 scc=(vg*10^3)/tz //short circuit current in ampears
19 disp('b')
20 printf(" generator impedance %.3fohm \n total
    impedance %.3f ohm \n short circuit current %.1fA
    ",gz,tz,scc)

```

Scilab code Exa 13.2 short circuit current parallel generator

```

1 clc
2 clear
3 disp('example 13.2')
4 pa1=20000 ;pa2=30000 //kva in in 3 ph power
5 va1=11 ;va2=11 //voltage in kilo volts
6 pt1=20000 ;pt2=30000//kva of 3 ph transformer
7 vpt1=11 ;vpt2=11//voltage of primery of
    transformer
8 vst1=132 ;vst2=132//voltage of secondary of
    transformer
9 xg1=0.5 ;xg2=0.65 //reactance of generator
10 xt1=0.05 ;xt2=0.05 //reactance of transformer with
    their own kva
11 pb=pa2;vbg=va2;vbt=vpt2;//assumeing base quantoties
12 xtn1=xt1*pb/pa1 ;xtn2=xt2*pb/pa2 //transformer
    reactance with new base
13 xgn1=xg1*pb/pa1;xgn2=xg2*pb/pa2
14 xn1=xtn1+xgn1;xn2=xtn2+xgn2 //reactancee up to
    fault from each generator
15 xn=(xn1*xn2)/(xn1+xn2) //equalent reactance between
    generator and fault

```

```

16 sckva=pb/xn ; //short circuit KVA
17 disp(' (a) ')
18 printf(" equivalent reactance is %.4f p.u \n short
        circuit KVA %dKVA",xn,sckva)
19 disp(' (b) ')
20 sccb=sckva/(vst1*sqrt(3))
21 sccg1=sccb*(xn2/(xn1+xn2))*vst1/vpt1
22 sccg2=sccb*(xn1/(xn1+xn2))*vst2/vpt2
23 printf(" short circuit current on bus bar side %.1fA
        \n short circuit current of generator 1 is %.1fA
        \n short circuit current of generator 2 is %.1fA
        \n",sccb,sccg1,sccg2)

```

Scilab code Exa 13.3 short circuit MVA

```

1 clc
2 clear
3 disp('example 13.3')
4 pa1=20000 ;pa2=30000 //kva in in 3 ph power
5 va1=11 ;va2=11 //voltage in kilo volts
6 pt1=20000 ;pt2=30000//kva of 3 ph transformer
7 vpt1=11 ;vpt2=11//voltage of primery of
  transformer
8 vst1=132 ;vst2=132//voltage of secondary of
  transformer
9 xg1=0.5 ;xg2=0.65 //reactance of generator
10 xt1=0.05 ;xt2=0.05 //reactance of transformer with
  their own kva
11 pb=pa2;vbg=va2;vbt=vpt2;//assumeing base quantoties
12 xtn1=xt1*pb/pa1 ;xtn2=xt2*pb/pa2 //transformer
  reactance with new base
13 xgn1=xg1*pb/pa1;xgn2=xg2*pb/pa2
14 xn1=xtn1+xgn1;xn2=xtn2+xgn2 //reactancee up to

```

```

    fault from each generator
15 xn=(xn1*xn2)/(xn1+xn2) //equalent reactance between
    generator and fault
16 sckva=pb/xn ; //short circuit KVA
17 pf=50000 //fault kva rating
18 xf=pb/pf //reactance from fault
19 xx=xf*xn1/(xn1-xf)
20 x=xx-xn2 //reactance to be added
21 bi=(vst1^2)*1000/(pb)
22 xo=x*bi
23 printf(" reactance to be added in circuit of
    generator 2 have %.1f p.u. \n reactance in ohms %
    .1f" ,x,xo)

```

Scilab code Exa 13.4 fault MVA in parallel generators

```

1 clc
2 clear
3 disp('example 13.4')
4 pa=50; xgb=0.5; xb=0.1; //given power, reactance of
    generator
5 x1=xgb+xb;
6 x=x1*x1*xgb/(x1*x1+x1*xgb+x1*xgb)
7 f=pa/x
8 printf(" total reactance %.4f.p.u \n fault MVA %.1
    fMVA" ,x,f)

```

Scilab code Exa 13.5 REATING OF CIRCUIT BREAKER

```

1  clc
2  clear
3  disp('example13_5')
4  vb=33
5  pb=20;zb=vb^2/pb    //base voltage and base power
6  pa1=10;pa2=10;xa1=0.08;xa2=0.08;    //given power and
    reactance for different branches
7  pbb=20;xb=0.06;pc=15;xc=0.12;pd=20;xd=0.08;
8  xab=2.17;xbc=3.26;xcd=1.63;xda=4.35;
9  xap1=xa1*pb/pa1;
10 xap2=xa2*pb/pa2;xap=xap1*xap2/(xap1+xap2)
11 xbp=xb*pb/pbb;
12 xcp=xc*pb/pc;
13 xdp=xd*pb/pd;    //generators reactance in per unit
14 xabp=round(xab*100/zb)/100;
15 xbcp=round(xbc*100/zb)/100;
16 xcdp=round(xcd*100/zb)/100;
17 xdap=round(xda*100/zb)/100    //reactance in per unit
    between bus
18 function [s1,s2,s3]=del2star(d12,d23,d31)
19     dsum=d12+d23+d31
20     s1=d12*d31/(dsum)
21     s2=d12*d23/(dsum)
22     s3=d31*d23/dsum
23 endfunction
24 function [d12,d31,d23]=star2del(s1,s2,s3)
25     d12=s1+s2+(s1*s2)/s3
26     d23=s2+s3+(s2*s3)/s1
27     d31=s3+s1+(s3*s1)/s2
28 endfunction
29 [xac,xrc,xra]=star2del(xcdp,xdap,xdp)
30 rc=xrc*xcp/(xrc+xcp)
31 ra=xra*xap/(xra+xap)
32 [xpr,xpc,xpa]=del2star(xac,rc,ra)
33 xf1=xbcp+xpc
34 xf2=xpr+xabp
35 xf=xf1*xf2/(xf1+xf2)
36 xfr=xf+xpa

```

```

37 xx=xfr*xbp/(xfr+xbp)
38 netr=xx //net reactance
39 fkva=pb*1000/xx
40 printf("the rating of circuit breaker should be %d
      KVA, or %d MVA",fkva,fkva/1000)

```

Scilab code Exa 13.6 ratio of mech stresses on short circuit to mech stresses on f

```

1 clc
2 clear
3 disp('example 13_6')
4 p=150 //given ,power
5 v=11 //given voltage
6 xg=0.12 //reactance of generator
7 xb=0.08 //reactance of line
8 scca=1/xg
9 ms=scca^2
10 sccb=1/(xg+xb)
11 ms1=sccb^2
12 disp('a')
13 printf("short circuit current is %.3fp.u \n ratio of
      mechanical stress on short circuit to aech.
      stresses on full load %.2f",scca,ms)
14 disp('b')
15 printf("short circuit current is with reactor %.3fp.
      u \n ratio of mechanical stress on short circuit
      to aech. stresses on full load with reactor %.f",
      sccb,ms1)

```

Scilab code Exa 13.7 percentage drop in bus bar voltage

```
1 clc
2 clear
3 disp('example13_7')
4 xf=complex(0,0.04)
5 pf=0.8;ph=acosd(pf)
6 v=1;i=1;//let v and i
7 vb=v+i*xf*(complex(cosd(ph),-sind(ph)))
8 iv=vb-abs(v);
9 printf("bus bar voltage %.4f.p.u at angle %.1f\n
  increase in voltage %.4f =%.4fpersent",abs(vb),
  atand(imag(vb)/real(vb)),iv,iv*100)
```

Scilab code Exa 13.8 short circuit MVA on hv and lv side

```
1 clc
2 clear
3 disp('example 13 8');
4 p1=30;x1=0.3 //power and reactance of different sets
5 p2=30;x2=0.3
6 p3=20;x3=0.3
7 l=10 ;x1=0.04
8 pb=p1;xp3=x3*pb/p3
9 tr=(xp3*x1*x2)/(xp3*x1+xp3*x2+x1*x2)
10 sc=pb/tr
11 disp('a')
12 printf("total reactance %.4f p.u \n short circuit
  MVA on l.v.bus %.2fMVA",tr,sc)
13 disp('b')
14 xlp=x1*pb/l
15 trr=tr+xlp
16 scc=pb/trr
```

```
17 printf("total reactance seen from h.v.side of
    transformer %.2fp.u \n short circuit MVA %.2fMVA"
    ,trr,scc)
```

Scilab code Exa 13.9 limiting the MVA with reactance

```
1 clc
2 clear
3 disp("example 13 9")
4 p1=30;x1=0.15;p2=10;x2=0.125;
5 pt=10;vs=3.3;pm=100
6 pb=p1 //let base as power of unit 1
7 x22=x2*pb/p2;x11=x1*pb/p1
8 xx=1/((1/x22)+(1/x11)+(1/x11))
9 x1=(pb/pm)-xx
10 xt2=x1*pt/pb
11 bi=vs^2/pt
12 xtt=xt2*bi
13 disp('a')
14 printf("reactance of transformer is %.4f.p.u \n
    reactance of transformer on %dMVA base is %.5fp.u
    . \n reactance of transformer %.4fohm",x1,pt,x1,
    xtt)
```

Scilab code Exa 13.10 fault current with different circuit

```
1 clc
2 clear
```

```

3 disp('example 13 10') //given //p=power/v=voltage/f=
    frequency/x=reactance/iff=feeder reactance take
    off
4 pa=20; va=11; f=50; xa=0.2; pb=30; xb=0.2; pf=10; xf=0.06;
    iff=0.5
5 pba=20; vba=11
6 xap=xa*pba/pb
7 xfp=xf*pba/pf
8 nx=xfp+(xa/2)*(xa/2+xap)/(xa+xap)
9 fcp=nx^(-1)
10 bc=pba*1000/(va*sqrt(3))
11 fc=fcp*bc
12 disp('a')
13 printf("fault current %.2fohm",fc)
14 ic=iff*fcp
15 xtx=ic^(-1)
16 xn=xtx-nx
17 zb=va^2/pba
18 xnn=xn*zb
19 disp('b')
20 printf("reactance required %.4fohm",xnn)

```

Scilab code Exa 13.11 fault level and fault MVA

```

1 clc
2 clear
3 disp('example 13 11')
4 n1=5; x=0.4; d=0.1; g=20 //given
5 mva=(g/x)+(g*(n1-1)/(x+n1*d))
6 n2=10 //given
7 mva2=(g/x)+(g*(n2-1)/(x+n2*d))
8 disp('a')
9 printf("fault MVA =(g/x)+(g*(n-1)/(x+nd)) \n fault

```



```
    level is to equal to fault MVA if n=infinity")
10 disp('b')
11 printf(" MVA=%0.2fMVA if n=%0d \n MVA=%0.2fMVA if n=%0d"
    ,mva,n1,mva2,n2)
12 f1=g*((1/x)+(1/d))
13 disp('c')
14 printf("\nfault level %dMVA",f1)
```

Chapter 14

SYSTEM INTERCONNECTIONS

Scilab code Exa 14.1 speed regulation and frequency drop in alternator

```
1  clc
2  clear
3  disp('example 14.1')
4  p=100 //rating of alternator
5  sd=0.04 //speed of alrternator drops
6  df=-0.1 //change in frequency and drops so -ve
7  f=50 //frequency is 50hz
8  r=sd*f/p //r in hz/MW
9  dp=-(df)/r
10 printf("speed regulation of alternator is %.2fHz/MW
    \n change in power output %dMW",r,dp)
```

Scilab code Exa 14.2 frequency deviation in alternator

```

1  clc
2  clear
3  disp('example14.2')
4  p=100 //power of alternator
5  f=50  //frequency
6  h=5   //h constant of machine kW-sec kVA
7  inl=50 //load suddenly increase by
8  de=0.5 //time delay
9  ke=h*p*10^3 //kinetic energy
10 lke=inl*10^3*de //loss in kinetic energy
11 nf=((1-(lke/ke))^(de))*f //now frequency
12 fd=(1-nf/f)*100 //frequency deviation
13 printf("kinetic energy stored at rated speed %.1e kW
    -sec \nloss in kinetic energy due to increase in
    load %.1e kW-sec \n new frequency %.3fHz \
    nfrequency deviation %.3f",ke,lke,nf,fd)

```

Scilab code Exa 14.3 speed regulation in sharing alternator

```

1  clc
2  clear
3  disp('example 14_3')
4  ar1=500 //alternator rating1
5  p1=0.5  //each alternator is operating at half load
6  ar2=200 //alternator rating2
7  f=50    //frequency
8  il=140  //load increase by 140 MW
9  fd=49.5 //frequency drops
10 fdd=-f+fd //frequency deviation
11 dp1=(ar1*p1)-il //change in load alternator 1
12 dp2=-(ar2*p1)+il //change in load of alternator 2
13 r1=-fdd/dp1
14 r2=-fdd/dp2

```

```
15 printf(" R1=%0.3fohm \n R2=%0.4fohm",r1,r2)
```

Scilab code Exa 14.4 static frequency drop for change in load

```
1 clc
2 clear
3 disp('example14.4')
4 rc=10000 //rated capacity
5 r=2 //regulation in all units
6 li=0.02 //load increase
7 f=50 //frequency
8 d=rc/(2*f) //d=partial derevative with respect to
   frequency
9 d=d/rc
10 b=d+1/r
11 m=li*rc/2
12 mpu=m/rc
13 df=-mpu/b
14 dff=-mpu/d
15 printf("static frequency drop %fHz \nfrequency drop
   %dHz",df,dff)
```

Scilab code Exa 14.5 primary ALFC loop paramers

```
1 clc
2 clear
3 disp('example 14.5')
4 cac=10000 //control area capacity
5 nol=5000 //normal operating
```

```

6 h=5          //inertial constant
7 r=3          //regulation
8 cf=1         //1%change in corresponds to 1% change in
    load
9 f=50         //frequency
10 d=cac/(2*f)
11 dpu=d/(cac)
12 kp=1/dpu
13 tp=2*h/(f*dpu)
14 printf("d=%0.2 fp.u.MW/hz , \nkp=%dhz/p.u.MW \n tp=
    %dsecond" ,dpu ,kp ,tp)

```

Scilab code Exa 14.6 frequency drop and increased generation to meet the increase

```

1 clc
2 clear
3 disp('example 14.6')
4 rc=10000 //rated capacity
5 r=2      //regulation in all units
6 li=0.02 //load increase
7 f=50     //frequency
8 d=rc/(2*f) //d=partial derevative with respect to
    frequency
9 dd=d/rc
10 b=dd+1/r
11 m=li*rc/2
12 mpu=m/rc
13 df=-mpu/b
14 dff=-mpu/dd
15 cf=abs(df*d)
16 inc=- (df/r)*10^4
17 printf("the contribution of frequency drop to meet
    increase in load %0.3fMW \nincrease in generation

```

```
cost Rs%.2f",cf,inc)
```

Scilab code Exa 14.7 frequency deviation before the value opens to meet the load d

```
1 clc
2 clear
3 disp('example 14.7')
4 p=100 //MVA of generated
5 f=50 //frequency
6 rpm=3000 //no load rpm
7 lad=25 //load applied to the machiene
8 t=0.5 //time delay
9 h=4.5 //inertia constent
10 ke=h*p //kinetic energy is product of h*p
11 lke=lad*t //loss of ke
12 nf=((ke-lke)/ke)^t*f //new frequency ((1-lke/ke)^
    t)*f
13 fd=(1-(nf/f))*100 //frequency deviation
14 printf("ke at no load %dMW-sec \n loss in k.e due to
    load %.1fMW-sec \nnew frequency %.1fHz \
    nfrequency deviation %.1fpercent",ke,lke,nf,fd)
```

Scilab code Exa 14.8 largest change in step load for constant duration of frequenc

```
1 clc
2 clear
3 disp('example 14.8')
4 c=4000 //capacity
5 f=50 //frequency
```

```

6 o1=2500 //operating load
7 r=2 //speed regulation
8 h=5 //inertial constant
9 dl=0.02 //change in load
10 df=0.01 //change in frequency
11 dff=-0.2 //change in steady state frequency
12 d=(dl*o1)/(df*f) //
13 dpu=d/c //din pu
14 b=dpu+(1/r)
15 m=-dff*b
16 printf("largest chang in load is %.3fp.u.MW=%dMW",m,
        m*c)
17 kp=(1/dpu)
18 tp=(kp)*2*h/f
19 tt=(r+kp)/(r*tp) //time constant
20 printf("\ndf=(dff)(1-e^%f*t)",tt)

```

Scilab code Exa 14.9 frequency response and static frequency error in the absence

```

1 clc
2 clear
3 disp('example14.9 ')
4 c=4000 //capacity of system
5 f=50 //frequency //operatingload=rated area
        capacity
6 h=5 //time constant
7 r=0.025 //
8 dl=0.01 //change in load
9 df=0.01 //change in frequency
10 rr=r*f //
11 d=(dl*c)/(df*f)
12 dpu=d/c
13 kp=1/dpu

```

```

14 tp=(kp)*(2*h/f)
15 tt=(rr+kp)/(rr*tp)
16 sfe=(kp*rr*dpu)/(rr+kp)
17 ki=(1+(kp/r))^2/(4*tp*kp)
18 printf(" df=%%.5 f(1-e^(-%%.1 f)) \n ki=%%.4 fp.u.MW/Hz",
        sfe,tt,ki)

```

Scilab code Exa 14.10 change in frequency in transfer function

```

1  clc
2  clear
3  disp('example14.10')
4  tg=0.2 //time constant of steam turbine
5  t=2 //time constant of turbine
6  h=5 //inertia constant
7  r=0.04 //given
8  dl=0.01 //change in load
9  df=0.01 //change in frequency
10 c=1500 //capacity
11 f=50 //frequency
12 adl=0.01 //max allowable change in load
13 printf("\ntransfer function of governor gr= 1/(1+%%.1
        f*s) \n transfer function of turbine gt=1/(1+%%d*s
        )",tg,t)
14 rr=r*f
15 d=(dl*c)/(df*f)
16 dpu=(d/c)
17 kp=(1/dpu)
18 tp=(kp*(2*h)/(f))
19 printf("\ntransfer function of power system \n Gp=(
        %%d/(1+%%d*s)\n Df=-gp/(1+(0.5*(gr*gt*gp)))",kp,tp)
20 ddf=-(kp)/(1+kp/r)
21 dff=df*f

```



```

22 m=dff/(ddf)
23 mm=m*c
24 disp('(b)')
25 printf("\nthe largest step in the load if the
        frequency change by more than %.2f in steady
        state %dMW",ad1,mm)
26 if mm<0
27     printf("\nthe minu sign is becose of the that if
        frequency is to increase by %f \nthe change
        in load be negative.",ad1)
28 else
29     printf("\nthe largest step in load if the
        frequency is to decrease by %f /n the change
        in load be positive",ad1)
30 end
31 disp('(c)')
32
33 disp('when integral controller is used,static
        frequency error is zero')

```

Scilab code Exa 14.11 stactic frequency drop and change in power line with peramet

```

1 clc
2 clear
3 disp('example 14_11')
4 pa=5000 //power of unit a
5 pb=10000 //power of unit b
6 r=2 //given speed regulation in p.uMW
7 d=0.01 //d in p.u.MW/Hz
8 dpa=0 //change in power in unit a
9 dpb=-100 //change in power in unit b
10 pbas=10000 //assume base as 10000
11 ra=r*pbas/pa //speed regulation of the unit a

```

```

12 da=d*pa/pbas //da of unit b
13 rb=r*pbas/pb //speed regulation of unit b
14 db=d*pb/pbas //db of unit b
15 ba=da+(1/ra) //area frequency response of a
16 bb=db+(1/rb) //area frequency response of b
17 ma=dpa/pbas //change in power a in per unit in
    unit a
18 mb=dpb/pbas //change in power a in per unit in
    unit b
19 df=(ma+mb)/(ba+bb) //change in frequency
20 dpab=(ba*mb-bb*ma)/(ba+bb) //change in power
    between ab
21 printf("change in frequency is %.5fHz \nchange in
    power %.6f p.u.MW",df,dpab)

```

Scilab code Exa 14.12 change in frequency and change power in different area

```

1 clc
2 clear
3 disp('example 14.12')
4 pa=500 //power of unit a
5 pb=2000 //power of unit b
6 ra=2.5 //speed regulation of a
7 rb=2 //speed regulation of b
8 dl=0.01 //change in load
9 df=0.01 // change in frequency
10 pt=20 //change in tie line power
11 ptl=0 //let other power station has zero
12 pbas=2000 //assume base as 2000MW
13 f=50 //assume frequency
14 da=(dl*pa)/(df*f) //change in power w.r.t frequency
15 dapu=da/(pbas) // change in power w.r.t frequency
    in per unit

```

```

16 db=(dl*pb)/(df*f) //change in power in unit b
17 dbpu=db/pbas //change in power w.r.t frequency
    in per unit
18 raa=ra*pbas/pa //speed regulation with pbase
19 rbb=rb*pbas/pb //speed regulation with pbase
20 ba=dapu+(1/raa) //area frequency response a
21 bb=dbpu+(1/rbb) //area frequency response b
22 ma=pt/pbas //assume change in power in unit a
    alone due to tie power
23 mb=ptl/pbas //change in power in unit b
24 df=- (ma+mb)/(ba+bb) //change in frequency
25 dpp=(ba*mb-bb*ma)/(ba+bb) //change in power
26 disp(' (a) ')
27 printf("change in frequency is %.3fHz \n change in
    power between ab %.5fp.u.MW \n \t\t%.2fMW",df,dpp
    ,dpp*pbas)
28 ma2=ptl/pbas //assume change in power in unit
    a alone due to tie power
29 mb2=pt/pbas //change in power in unit b
30 df2=- (ma2+mb2)/(ba+bb) //change in frequency
31 dpp2=(ba*mb2-bb*ma2)/(ba+bb) //change in power
32 disp(' (b) ')
33 dpba=dpp2*pbas
34 printf("change in frequency is %.3fHz \n change in
    power between ab %.5fp.u.MW \n",df2,dpp2)
35 printf(" change in power %fMW",dpba)

```

Scilab code Exa 14.13 steady state change in tie line power if step change in power

```

1 clc
2 clear
3 disp('example 14.13 ')
4 p=4000 //power area

```

```

5 n=2      //number of units
6 r=2      //speed regulation
7 h=5
8 pt=600   //given tie power
9 pan=40   //power angle
10 stp=100
11 f=50
12 t=(pt/p)*cosd(pan)
13 wo=((2*pi*f*t/h)^2-(f/(4*r*h))^2)^(0.5)
14 printf("the damped angular frequency is %.2fradians/
      sec if speed govenor loop is closed",wo)
15 disp('(b)')
16 printf("since the two area are imilier ,each area
      will supply half of increase in load .this also
      evident besause ba=bb \n change in power %dMW \n
      speed regulation is infininy",stp/2)
17 wo1=(2*pi*f*t/h)^(0.5) //if govenor loop is open
      alpha is zero
18 printf("damped angular frequency if speed governor
      loop is open %.3frad/sec ",wo1)

```

Scilab code Exa 14.14 capacitance of shunt load capacitor to maintain voltage cons

```

1 clc
2 clear
3 disp('example14.14')
4 Aa=0.98;Ap=3 //magnitude and angle of constant A
5 Ba=110;Bp=75 //magnitude and angle of constant B
6 p=50 //given power 50
7 pf=0.8 //given power factor is 0.8
8 vr=132 //voltage at reseving station
9 vs=132 //voltage at source station to be maintained
10 vsr1=p*pf+(Aa*(vr^2)/Ba)*cosd(Bp-Ap)

```

```

11 ph=vsr1*Ba/(vs*vr)
12 phh=acosd(ph)
13 del=Bp-phh
14 qrr=((vs*vr/Ba)*sind(phh))-((Aa*(vr)^(2)/Ba)*sind(Bp
    -Ap)) //reactive power to maintain voltage equal
15 qrre=p*sind(acosd(pf)) //reactive power for the load
16 qrc=qrre-qrr
17 printf("the reactive power supply and reseving power
    is %dkV \nreactive power %.2fMvar",vs,qrr)
18 printf("\nthe required compensator network needed %
    .2fMvar",qrc)
19 disp('(b)')
20 cosb=(Aa*cosd(Bp-Ap)*(vr)^(2)/Ba)*(Ba/(vs*vr)) //
    under no oad condition
21 phb=acosd(cosb)
22 qrb=(vs*vr*sind(phb)/Ba)-(Aa*vr*vr*sind(Bp-Ap)/Ba)
23 if qrb>0 then
24     printf("thus under no load condition the line
        delivers %.2fMvar at receiving end.the
        reactive power must be absorbed by shunt
        reactor at receving end. thus the capacity of
        shunt reactor , for no load condition is %.2
        fMvar. ",qrb,qrb)
25 else
26     printf("thus under no load condition the line
        absorbs %.2fMvar at receiving end.the
        reactive power must be delivered by shunt
        reactor at receving end. or reactive must
        supplied by the source thus the capacity of
        shunt reactor , for no load condition is %.2
        fMvar. ",qrb,qrb)
27 end

```

Scilab code Exa 14.15 maintaining voltage constant by tapping transformer

```
1 clc
2 clear
3 disp('example 14.15')
4 v=220 //line voltage
5 ps=11 ;ss=220;pr=220;sr=11 //primer and secondary
    end terminal voltages of tapping transformer
6 zr=20;zi=60 //impedence of line in real ndimaginary
    parts
7 p=100 //power at recieving end is 100MVA
8 pf=0.8 //power factor at recievin end
9 t=1 //product of 2 off terminal tap setting is 1
10 vt=11 //tap setting for 11 kv voltage bus
11 P=(p*pf*10^6)/3 //real power
12 Q=(p*sind(acosd(pf))*10^6)/3 //reactance power
13 v1=v*(10^3)/sqrt(3)
14 ts=(1/(1-(zr*P+zi*Q)/(v1^2)))^(0.5)
15 printf(" tapping ratio at the source %.3f \n
    tapping ratio at the receiving end %.2f",ts,1/ts)
```

Scilab code Exa 14.16 output voltage with reactive power

```
1 clc
2 clear
3 disp('example 14.16')
4 vp=132;vs=33;vt=11 //voltage at primary ,secondary
    ,teritiory
5 pp=75;ps=50;pt=25 //MVA rating at primary ,
    secondary ,teritiory
6 rpr=0.12;rv=132;rp=75 //reactance power of primary
    under rv and rp as voltage and power base
7 poa=60;rea=50 //load real and reactive power a
```

```

8 pva=125;svaa=33 //primary and secondary voltage a
9 svsb=25;pvb=140;svbb=33 //primary and secondary
  voltage at no load
10 disp(' (a) ')
11 vbas=132 ;mvabas=75 //assume voltage and MVA base
12 v1pu=pva/vbas //voltage in per unit
13 v1apu=round(v1pu*1000)/1000 //rounding off
14 qre=rea/mvabas //reactive power in per unit
15 vn1a=(v1apu+sqrt(v1apu^2-4*rpr*qre))/2 //voltage
  using quadratic equation formulae
16 vn2a=(v1apu-sqrt(v1apu^2-4*rpr*qre))/2
17 vn1a=vn2a*vbas
18 v12=pvb/vbas
19 q=svsb/mvabas
20 vn1b=(v12+sqrt(v12^2-4*rpr*q))/2 //voltage using
  quadratic equation formulae
21 vn1b=round(vn1b*1000)/1000
22 vnbb=vn1b*vbas //vn in no load condition
23 printf("vn=%0.3f p.u \n vn=%0.3fkV",vn1a,vn1a)
24 disp(' (b) ')
25 printf("vn=%0.3f p.u \n vn=%0.3fkV",vn1b,vn1b)
26 z=vn1a/svaa;x=vn1b/svbb;
27 printf("\n transformation ratio under load condition
  %0.3f \n transformation ratio under no load
  condition %0.3f \n the actual ratio can be taken
  as mean of the above value i.e.%0.3fpercent\n
  varying by (+/-)%0.3fpercent",z,x,(z+x)/2,x-(z+x)
  /2)

```

Scilab code Exa 14.17 generation at each station and transfer of power of differen

```

1 clc
2 clear

```

```

3 disp('example 14.7')
4 ca=200 //capacity of unit a
5 cb=100 //capacity of unit b
6 ra=1.5 //speed regulation of unit a
7 rb=3 //speed regulation of unit b
8 f=50 //frequency
9 pla=100 //load on each bus
10 plb=100
11 raa=ra*f/(pla*ca)
12 rbb=rb*f/(plb*cb)
13 pa=rbb*(pla+plb)/(raa+rbb)
14 pb=pla+plb-pa
15 tp=pa-pla
16 printf(" generation at the plant a is %dMW and \n
generation at the plant b is %dMW \n transfer
power from plant a to b is %dMW",pa,pb,tp)

```

Scilab code Exa 14.18 current transfer between two station

```

1 clc
2 clear
3 disp('example 14.18')
4 za=1.5;zb=2.5;//impedence between two lines
5 v=11 //plant operatio\ng voltage
6 l=20 ; pf=0.8 ;//load at 20 MW at 0.8 pf
7 i=1*10^3/(v*pf*sqrt(3));ph=-acosd(pf) //current and
phase angle of transfrming current
8 vd=complex(za,zb)*complex(i*cosd(ph),i*sind(ph)) //
voltage drop due to loss
9 printf("the current transfer is %.1fA at an angle %
.2f",i,ph)
10 printf("\nvoltage drop in the interconnector is %.2f
+j%.2fV \n so voltage boost needed is %.2f+j%.2fV

```



```
”,real(vd),imag(vd),real(vd),imag(vd))
```

Scilab code Exa 14.19 current in interconnector with different power factor

```
1 clc
2 clear
3 disp('example 14.19')
4 zaa=3;zbb=9 //impedence given between line
5 pas=1 //power at two units are equal to 1p.u
6 par=1
7 pbs=1.05 //power at sending end is 1.05 and power
   at receiving end is 1p.u
8 pbr=1
9 i=1 //assume current is 1p.u
10 los=i*complex(zaa/100,zbb/100)
11 csd=((abs(los)^2)-pas^2-par^2)/(2*pas*par) //load
   angle between two stations
12 csa=(pas^2+abs(los)^2-par^2)/(2*pas*abs(los)) //
   angle between source and loss
13 ta=180-atan(zbb/zaa)-acosd(csa) //transferring
   power factor angle
14 printf("load angle is %.2f\n",cosd(csd))
15 if sind(ta)<0 then
16     printf("real power is %.3fp.u \nreactive power %
   .3fp.u lagging",cosd(ta),abs(sind(ta)))
17 else
18     printf("real power is %.3fp.u \nreactive
   power %.3fp.u leading",cosd(ta),sind(
   ta))
19
20 end
21 csd2=(abs(los)^2-pbs^2-pbr^2)/(2*pbs*pbr) //load
   angle between two stations
```

```

22 csa2=(pbr^2-pbs^2+abs(los)^2)/(2*pbr*abs(los)) //
    angle between source and loss
23     f=180-atan(zbb/zaa)-acosd(csa2) //transferring
        power factor angle
24 disp('(b)')
25
26 printf("load angle is %.2f\n",cosd(csd2))
27 if sind(f)<0 then
28     printf("real power is %.3fp.u \nreactive power %
        .3fp.u lagging",cosd(f),abs(sind(f)))
29 else
30     printf("real power is %.3fp.u \nreactive
        power %.3fp.u leading",cosd(f),sind(f)
        )
31
32 end

```

Chapter 15

NEW ENERGY SOURCES

Scilab code Exa 15.1 open circuit voltage internal resistance maximum power in MHD

```
1 clc
2 clear
3 disp('example 15.1')
4 a=0.1 //plate area
5 b=3 //flux density
6 d=0.5 //distance between plates
7 v=1000 //average gas velocity
8 c=10 //conductivity
9 e=b*v*d
10 ir=d/(c*a) //internal resistance
11 mapo=e^2/(4*ir) //maximum power output
12 printf("E=%dV \ninternal resistance %.1fohm \
nmaximum power output %dW =%.3fMW",e,ir,mapo,mapo
/10^6)
```

Scilab code Exa 15.2 open circuit voltage gradient in duct due to load in MHD engi

```

1  clc
2  clear
3  disp('example 15.2')
4  b=4.2 //flux density
5  v=600 //gas velocity
6  d=0.6 //dimension of plate
7  k=0.65 //constant
8  e=b*v*d //open circuit voltage
9  vg=e/d //voltage gradient
10 v=k*e //voltage across load
11 vgg=v/d //voltage gradient due to load voltage
12 printf("voltage E=%dV \n voltage gradient %dV/m \n
         voltage across load %.1fV \n voltage gradient due
         to load voltage %dv",e,vg,v,vgg)

```

Scilab code Exa 15.3 losses in duct power delivered to load efficiency current den

```

1  clc
2  clear
3  disp("example 15.3")
4  b=4.2 //flux density
5  v=600 //gas velocity
6  d=0.6 //dimension of plate
7  k=0.65 //constant
8  sl=0.6 //length given
9  sb=0.35 //breath given
10 sh=1.7 //height given
11 c=60 //given conductivity
12 e=b*v*d //open circuit voltage
13 vg=e/d //voltage gradient
14 v=k*e //voltage across load
15 vgg=v/d //voltage gradient due to load voltage
16 rg=d/(c*sb*sh)

```

```

17 vd=e-v //voltage drop in duct
18 i=vd/rg //current due to voltage drop in duct
19 j=i/(sb*sh) //current density
20 si=e/(rg) //short circuit current
21 sj=si/(sb*sh) //short circuit current density
22 pd=j*vg //power density
23 p=pd*sl*sh*sb //power
24 pp=e*i //also power
25 pde=v*i //power delevered is V*i
26 los=p-pde //loss
27 eff=pde/p //efficiency
28 maxp=e^2/(4*rg)
29 printf("resistence of duct %fohms \n voltage drop in
duct %.1fV \n current %.1fA \ncurrent density
%fA/m^2 \nshort circuit current %.1fA \nshort
current density %fA/m^2 \n power %dMW \npower
delivered to load %fW \n loss in duct %fW \
nefficiency is %f \nmaximum power delivered to
load %dMW",rg,vd,i,j,si,sj,p/10^6,pde/10^6,los
/10^6,eff,maxp/10^6)

```

Scilab code Exa 15.4 output voltage maximum power output in MHD generator

```

1 clc
2 clear
3 disp("example 15.4")
4 c=50 //conduntance
5 a=0.2 //area
6 d=0.24 //distince between electrodes
7 v=1800 //gas velocity
8 b=1 //flux density
9 k=0.7
10 ov=k*b*v*d

```

```

11 tp=c*d*a*b^2*v^2*(1-k)
12 eff=k
13 op=eff*tp
14 e=b*v*d
15 rg=d/(c*a)
16 si=e/rg
17 maxp=e^2/(4*rg)
18 printf("output voltage %.1fV \ntotal power %.4fMW \n
    efficiency %.1f \n output power %fMW \n open
    circuit voltage %dV \n internal resistance %.3
    fohm \n short circuit current %dA \n maximum
    power output is %.3fMW",ov,tp/10^6,eff,op/10^6,e,
    rg,si,maxp/10^6)

```

Scilab code Exa 15.5 power collected by surface of collector and temperature rise

```

1 clc
2 clear
3 disp('example 15.5')
4 a=100 //area
5 spd=0.7 //sun light power density
6 m=1000 //weight of water collector
7 tp=30 //temperature of water
8 th2=60 //angle of incidence
9 cp=4186 //specific heat of water
10 sp=spd*cosd(th2)*a //solar power collected by
    collector
11 ei=sp*3600*10^3 //energy input in 1 hour
12 temp=ei/(cp*10^3)
13 tw=tp+temp
14 printf("solar power collected by collector %dkW \
    nenergy input in one hour %e J \n rise in
    temperature is %.1f'C \n temperature of water %.1

```

```
f 'c', sp, ei, temp, tw)
```

Scilab code Exa 15.6 peak watt capacity of PV panel and number of modules of photo

```
1 clc
2 clear
3 disp('example 15.6')
4 vo=100 //motor rated voltage
5 efm=0.4 //efficiency of motor pump
6 efi=0.85 //efficiency of inverter
7 h=50 //head of water
8 v=25 //volume of water per day
9 ov=18 //pv pannel output module
10 pr=40 //power rating
11 ao=2000 //annual output of array
12 dw=1000 //density of water
13 en=v*dw*h*9.81 //energy needed to pump water every
    day
14 enkw=en/(3.6*10^6) //energy in kilo watt hour
15 oe=efm*efi //overall efficiency
16 epv=round(enkw/oe) //energy out of pv system
17 de=ao/365 //daily energy output
18 pw=epv*10^3/de //peak wattage of pv array
19 rv=vo*(%pi)/sqrt(2) //rms voltage
20 nm=rv/ov //number of modules in series
21 nm=ceil(nm)
22 rpp=nm*pr //rated peak power output
23 np=pw/rpp //number of strings in parallel
24 np=round(np)
25 printf(" energy needed o pump water every day %fkWh/
    day \n overall efficiency %.2f \n energy output
    of pv system %dkWh/day ", enkw, oe, epv)
26 printf("\n annual energy out of array %dWh/Wp \n")
```

```

    ndaily energy output of array %.3fWh/Wp \n peak
    wattage of pv array %.2fWp \n rms output voltage
    %.2fV\nnumber of modules in series %d \n rated
    peak power output of each string %.2fW \n number
    of strings in parallel %d", epv, de, pw, rv, nm, rpp, np
)

```

Scilab code Exa 15.7 power available power density torque at maximum power of wind

```

1  clc
2  clear
3  disp("example 15.7")
4  ws=20 //wind speed
5  rd=10 //rotor diameter
6  ros=30 //rotor speed
7  ad=1.293 //air density
8  mc=0.593 //maximum value of power coefficient
9  p1=0.5*ad*(%pi)*(rd^2)*(ws^3)/4 //power
10 p=p1/10^3
11 pd=p/((%pi)*(rd/2)^2) //power density
12 pm=p*(mc) //maximum power
13 mt=(pm*10^3)/((%pi)*rd*(ros/60))
14 printf("power %.fkW \n power density %.3fkW/m^3 \
    nmaximum power %fkW \n maximum torque %.1fN-m", p,
    pd, pm, mt)

```

Scilab code Exa 15.8 difference pressure in pascals and other unit of wind mill

```

1  clc

```



```

2 clear
3 disp("example 15.8")
4 cp=0.593
5 d=1.293
6 s=15
7 a=2/3
8 dp=2*d*(s^2)*a*(1-a)
9 dlp=760*dp/(101.3*10^3) //760 mmhg=101.3*10^3 pascal
   then pressure in mm of hg
10 dpa=dlp/760 //pressure in atmosphere
11 printf("pressure in pascal %.1fpascal \npressure in
   height of mercury %.2fmm-hg \npressure in
   atmosphere %.5fatm",dp,dlp,dpa)

```

Scilab code Exa 15.9 output surface area of reservoir in tidal power plant

```

1 clc
2 clear
3 disp("example 15.9")
4 ng=50 //number of generator
5 r=30 //rated power
6 mah=10 //maximum head
7 mih=1 //minimum head
8 tg=12 //duration of generation
9 efg=0.9 //efficiency of generated
10 g=9.81 //gravity
11 le=5 //lenght of embankment
12 ro=1025 //density
13 ti=r/(0.9)^2
14 q=ti*10^(6)/(ro*g*mah) //maximum input
15 q=floor(q*10^2)/10^2
16 qw=q*ng //total quantity of water
17 tcr=qw*tg*3600/2 //total capacity of resevoir

```

```

18 sa=tcr/mah //surface area
19 wbe=sa/(1e*10^6) //wash behind embankment
20 avg=r/2
21 te=avg*tg*365*ng //total energy output
22 printf("quantity of water for maximum output %fm^3-
    sec ",q)
23 printf("\nsurface area of reservoir %fkm^3 ",sa
    /10^6)
24 printf("\nwash behind embankment %fkm \ntotal energy
    output %eMWh",wbe,te)

```

Scilab code Exa 15.10 comparison between tidel and coal plant

```

1 clc
2 clear
3 disp('example 15.10')
4 tc=2100 //total capacity of plant
5 n=60 //number of generaed
6 p=35 //power of generated by each generator
7 h=10 //head of water
8 d=12 //duration of generation
9 cee=2.1 //cost of electrical energy per kWh
10 efft=0.85 //efficiency of turbine
11 effg=0.9 //efficiency of generator
12 g=9.81 //gravity
13 ro=1025 //density
14 acc=0.7 //assuming coal conumotion
15 pi=p/(efft*effg) //power input
16 q=pi*10^6/(h*g*ro) //quantity of water
17 tqr=q*n*d*3600/2 //total quantity of water in
    reservoir
18 avp=tc/2 //average output during 12h
19 toe=avp*d //total energy in 12 hours

```

```
20 eg=toe*365 //energy generated for total year
21 coe=eg*cee*10^3 //cost of electrical energy
    generated
22 sc=eg*10^3*acc //saving cost
23 printf("total quantity of water in reservoir %em^3 \
    nenergy generated per year %eMW \ncost of
    electrical energy Rs%e \nsaving in cost Rs.%e ",
    tqr, eg, coe, sc)
```

Chapter 17

GENERATING CAPACITY RELIABILITY EVALUATION

Scilab code Exa 17.1 CAPACITY OUTAGE PROBABILITY TABLE

```
1  clc
2  clear
3  disp(" example 17.1 ")
4  //given
5  n=2 //number of generating station
6  f=0.03 //F.O.R
7  a=1-f
8  p=40 //generation station power
9  function [y]=comb(m,r)
10 y=factorial(m)/(factorial(m-r)*factorial(r))
11 endfunction
12 for i=0:n
13     pg(i+1)=comb(n,i)*((f)^i)*((a)^(n-i))
14     printf("\nnumber of units out %d ,capacity out
           %dMW ,capacity available %dMW ,probability
           %4f ",i,p*i,p*(n-i),pg(i+1))
15 end
```

Scilab code Exa 17.2 CAPACITY OUTAGE PROBABILITY TABLE AND CUMMULATIVE PROBABILITY

```

1  clc
2  clear
3  disp("example 17 2")
4  //given
5  n1=2 //number of generating station
6  f1=0.03 //F.O.R
7  a1=1-f1
8  p1=40 //genetaion station power
9  n2=1 //number of genreting station
10 f2=0.03 //F.O.R for second set
11 a2=1-f2
12 p2=30 //generating station power in second set
13 function [y]=comb(m,r)
14 y=factorial(m)/(factorial(m-r)*factorial(r))
15 endfunction
16 for i=0:n2
17     pg2(i+1)=comb(n2,i)*((f2)^i)*((a2)^(n2-i))
18     co2(i+1)=p2*i;ca2(i+1)=p2*(n2-i)
19     printf("\nnumber of units out %d ,capacity out
           %dMW ,capacity available %dMW ,probability
           %4f ",i,co2(i+1),ca2(i+1),pg2(i+1))
20 end
21 printf("\nfor exp 17 1 ")
22 for i=0:n1
23     pg1(i+1)=comb(n1,i)*((f1)^i)*((a1)^(n1-i))
24     co1(i+1)=p1*i;ca1(i+1)=p1*(n1-i)
25     printf("\nnumber of units out %d ,capacity out
           %dMW ,capacity available %dMW ,probability
           %4f ",i,co1(i+1),ca1(i+1),pg1(i+1))
26 end

```

```

27 printf("\ncombination of 2 set of stations")
28 tp=1
29 pocg=0
30 for i=0:n1
31     for j=0:n2
32         og=co1(i+1)+co2(j+1) //now total system
            capacity out
33         cg=ca1(i+1)+ca2(j+1) //now total system
            capacity available
34         tp=tp-pocg
35         pocg=pg1(i+1)*pg2(j+1) //individual stste
            probability
36         printf("\ncapacity out %dMW ,capacity
            available %dMW ,individual state
            probability %.6f ,cumulative probability
            %.6f" ,og ,cg ,pocg ,tp)
37     end
38 end

```

Scilab code Exa 17.3 CAPACITY OUTAGE PROBABILITY TABLE AND CUMMULATIVE PROBABILITY

```

1 clc
2 clear
3 disp("example 17 3")
4 //given
5 n=4 //number of generating station
6 f=0.05 //F.O.R
7 a=1-f
8 p=50 //generation station power
9 mp=150 //maximum allowable power
10 lf=50 //load factor in persentage

```




Figure 17.1: CAPACITY OUTAGE PROBABILITY TABLE AND CUM-
MULATIVE PROBABILITY

```

11 function [y]=comb(m,r)
12 y=factorial(m)/(factorial(m-r)*factorial(r))
13 endfunction
14 for i=0:n
15     pg(i+1)=comb(n,i)*((f)^i)*((a)^(n-i))
16     co(i+1)=p*i;ca(i+1)=p*(n-i)
17     printf("\nnumber of units out %d ,capacity out
           %dMW ,capacity available %dMW ,probability
           %4f ",i,co(i+1),ca(i+1),pg(i+1))
18 end
19 ld=mp:-lf:0
20 [m n]=size(ld)
21 plot(ld)
22 tg(n-1)=round(10000/(n-1))/100
23 tg(n)=tg(n-1)*2
24 tg(n+1)=100
25 tg(2)=0;tg(1)=0 //maximum load limit
26 for i=0:n
27     el(i+1)=pg(i+1)*tg(i+1)
28     printf("\nnumber of units out %d ,capacity out
           %dMW ,capacity available %dMW ,probability
           %4f ,tg in percentage %.2f ,expected load %.6
           fMW",i,co(i+1),ca(i+1),pg(i+1),tg(i+1),el(i
           +1))
29 end
30 lt=sum(el)
31 printf("\n\nexpected loss of load is %.6fMW percent
           of time. assuming 365 days in a year , then
           expected loss of load is %.3fMW days per year",lt
           ,lt*365/100)

```




Figure 17.2: CAPACITY OUTAGE PROBABILITY TABLE AND EXPECTED LOAD

Scilab code Exa 17.4 CAPACITY OUTAGE PROBABILITY TABLE AND EXPECTED LOAD

```

1  clc
2  clear
3  disp("example 17 4")
4  //given
5  n=4 //number of generating station
6  f=0.02 //F.O.R
7  a=1-f
8  p=50 //generation station power
9  mp=150 //maximum allowable power
10 minp=30 //minimum power
11 lf=60 //load factor in percentage
12 function [y]=comb(m,r)
13 y=factorial(m)/(factorial(m-r)*factorial(r))
14 endfunction
15 for i=0:n
16     pg(i+1)=comb(n,i)*((f)^i)*((a)^(n-i))
17     co(i+1)=p*i;ca(i+1)=p*(n-i)
18     printf("\nnumber of units out %d ,capacity out
           %dMW ,capacity available %dMW ,probability %
           .7f ",i,co(i+1),ca(i+1),pg(i+1))
19 end
20 ld=mp:-lf:minp
21 [m n1]=size(ld)
22 [mm m]=max(co)
23 plot(ld)
24 tg(1)=0
25 for i=2:n+1
26     tg(i)=(mp-ca(i))*100/(2*lf) //percentage time
27 end
28 disp(" ")
29 for i=1:n+1
30     el(i)=pg(i)*tg(i)
31     printf("\nnumber of units out %d ,capacity out
           %dMW ,capacity available %dMW ,probability
           %4f ,tg in percentage %.2f ,expected load %.6
           fMW",i-1,co(i),ca(i),pg(i),tg(i),el(i))

```

```
32 end
33 lt=sum(e1)
34 printf("\n\nexpected loss of load is %.6fMW percent
of time. assuming 365 days in a year , then
expected loss of load is %.3fMW days per year ,
some times the loss of load is also expressed as
reciprocal of this figure and then the units are
years per day this result is %.4fMW years per day
.",lt,lt*365/100,100/(lt*365))
```

Chapter 20

ENERGY AUDIT

Scilab code Exa 20.1 economic power factor electricity bill

```
1  clc
2  clear
3  disp('example 20.1 ')
4  lod=1 //industrial installation load
5  pf=0.78 //power factor
6  tf=200 //tariff
7  md=3.5 //extra maximum demand
8  ic=500 //installation of capacitor
9  id=0.15 //interest and depreciation
10 lf=0.8 //load factor
11 smp=ic*id/tf
12 ph2=asind(smp)
13 epf2=cosd(ph2)
14 ph1=acosd(pf)
15 ph1=round(ph1*10^2)/10^2
16 ph2=round(ph2*10^2)/10^2
17 q=lod*(tand(ph1)-tand(ph2))
18 q=round(q*10^4)/10^4
19 ikva=lod/pf
```

```

20 ikv=round(ikva*(10^5))/10^2
21 aeu=lod*lf*8760*10^6
22 eb=ikv*tf+aeu*md
23 printf("(a)\neconomic power factor %.3flagging \n(b)
    \ncapacitor kVAR to improve the power factor %.4
    f \n(c) \ninitial kVA %.2fKVA \nannual energy
    used %0.3ekWh \nelectrical bill Rs%e per year",
    epf2,q,ikv,aeu,eb)
24 kvc=round((lod*10^3/(round(epf2*1000)/10^3))*10^2)
    /10^2
25 ebc=kvc*tf+aeu*md
26 aidc=q*10^3*ic*id
27 te=ebc+aidc
28 asc=eb-te
29 printf("\n(d)\nKVA after installation of capacitors
    %.2fKVA \n",kvc)
30 printf("energy bill after installation of capacitor
    Rs%e per year \n",ebc)
31 printf("annual interest and depreciation of
    capacitor bank Rs%.1fper year \ntotal expenditure
    after installation of capacitors Rs%e per year \
    n annual savings due to installation of
    capacitors Rs%d per year",aidc,te,asc)

```

Scilab code Exa 20.2 annual cost method present worth method

```

1 clc
2 clear
3 disp('example 20.2')
4 ee=5*10^16 //electrical energy requirement
5 eer=0.1 //energy requirement
6 i=5*10^6 //investement
7 n=20 //life time

```

```

8 ec=4.1 //energy cost
9 r=0.13 //interest rate
10 dr=r/((1+r)^(n)-1) //depreciation rate
11 dr=round(dr*10^5)/10^5
12 tfc=r+dr //total fixed cost
13 ace=i*tfc //annual cost
14 ace=round(ace/10^2)*10^2
15 eb=i*ec //electrical bill with present motor
16 teb=eb*(1-eer) //electrical bill with efficiency
    motor
17 tac=teb+ace //total annual cost with efficiency
    cost
18 as=eb-tac //annual saving
19 printf(" depreciation rate %.5f \n total fixed
    charge rate %f\n annual cost of efficiency motor
    Rs%eper year \n total electrical bill with
    present motors Rs%eper year \n total electrical
    bill with efficiency motor Rs.%e \n total annual
    cost if motors are replaced by high efficiency
    motors Rs%e per year \n annual saving Rs%d per
    year",dr,tfc,ace,eb,teb,tac,as)
20 disp('b')
21 pwf=r/(1-((1+r)^-n)) //present worth factor
22 pwf=round(pwf*10^5)/10^5
23 pwm=teb/pwf //present worth annual cost with
    existing motors
24 pwm=round(pwm/10^4)*10^4 //present worth with
    existing motors
25 pwem=eb/pwf //present worth with efficiency motor
26 pwem=round(pwem/10^4)*10^4
27 pwam=teb/pwf
28 pwam=round(pwam/10^4)*10^4
29 tpw=pwam+i //total present worth
30 printf("present worth factor %.5f \n present worth
    of annual cost with existing motors Rs%e \n
    present worth of annual cost with new motor Rs%e
    \n total present worth %e per year",pwf,pwem,pwam
    ,tpw)

```


Chapter 23

CAPTIVE POWER GENERATION

Scilab code Exa 23.1 COST OF DIESEL ENGINE CAPITIVE POWER PLANT

```
1  clc
2  clear
3  disp('example:23.1')
4  sp=11*10^3;pc=300*10^6;ir=0.15;lp=15;fc=7;eff=0.35;
   cv=10100;mc=0.02;lf=0.8;er=860 //let the given
   variable be --sp=size of plant ,pc=project cost ,
   ir=interest rate ,lp=life of the plant ,fc=fuel
   cost , eff=efficiency ,cv=calorific value ,er=860,mc=
   maintenance cost ,lf=load factor ,
5  cac=pc/sp //let the variable cac be captel cost
6  printf("\ncapitel cost is %.1f/kW",cac)
7  crfd1=(1+ir)^(-lp)
8  crfd=1-crfd1
9  crf=ir/crfd //crf=capitel cost recovery factor
10 printf("\nCRF=%.3f",crf)
11 anfc=cac*crf //annual fixed cost is propect of
   capitel cost and capitel recovery factor
```



```

12 printf("\nannual fixed cost is Rs%.2f/kW",anfc)
13 hr=er/eff //heat rate is energy ratedivided by
    efficiency
14 printf("\nheat rate is %fcal/kWh",hr)
15 gpf=cv/hr;//kW generated per liter is division of
    calorific value to hr
16 printf("\nnumber of kWh generated per liter of fuel
    is %.2fkWh/litre",gpf)
17 fcp=fc/gpf //fuel cost per unit is fuel cost divided
    by generated per liter
18 printf("\nfuel cost per unit Rs%fper kWh",fcp)
19 aomc=cac*mc //annual operation and maintenance cost
20 printf("\nannual operation cost Rs.%.4f/kW",aomc)
21 afom=anfc+aomc
22 printf("\nannual fixed , operation and maintence cost
    Rs.%.2f/kW",afom)
23 egpy=8760*lf //energy generated is 24*12*60
24 printf("\nenergygenerated per year is %dkWh",egpy)
25 afomc=afom/egpy
26 printf("\nannual fixed operation and maintenance
    cost per kWh of energy %.4f/kWh",afomc)
27 gco=fcp+afomc //generated cost is sum of fuel cost
    and maintenance cost
28 printf("\ngenerated cost is Rs%.4f/kWh",gco)

```

Scilab code Exa 23.2 GENERATION COST OF CAPITIVE POWER PLANT in suger mill

```

1 clc
2 clear
3 disp('example 23.2')
4 sp=25*10^3 //size of the plant
5 cc=800*10^6 //capital cost
6 ir=0.1 //interest rate

```

```

7 lp=20      //life of the plant
8 mc=0.05    //maintenance cost
9 lf=0.6     //load factor
10 sub=0.3   //subsidy
11 nc=cc*(1-sub)
12 nck=nc/sp
13 crf=ir/(1-(1+ir)^(-lp))
14 afc=nck*crf
15 aomc=nck*mc
16 tac=afc+aomc
17 aeg=8760*lf
18 gc=tac/aeg
19 printf("net capital cost Rs%d*10^6 \nnet capital
   cost per KW Rs%f/kW \ncrf %f \nannual fixed cost
   Rs%d per kW \nannual operation and maintenance
   cost Rs%dper kW \nTotal annual cost Rs%dper kW \
   nAnnual energy generated per kW of plant capacity
   %.1fkWh \ngeneration cost Rs%.3fkWh",nc/(10^6),
   nck,crf,afc,aomc,tac,aeg,gc)

```

Scilab code Exa 23.11.2 calculation of wheeling charges

```

1 clc
2 clear
3 disp("sample problem in 23.11.2")
4 pp=11 //power capacity
5 cost=35 //cost of the system
6 in=0.14 //interest
7 lis=30 //life of system
8 sv=0.15 //salvage value
9 es=13.5*10^6 //energy sent
10 los=0.05 //losses
11 omc=0.02 //O&M charges
12 gr=0.006 //general revenue
13 rd=(1-sv)*100/lis

```

```
14 rdd=rd/100
15 tac=cost*(in+omc+rdd+gr)
16 ery=es*(1-los)
17 wc=(tac/ery)*10^5
18 printf("rate of depreciation is %.3fpercent \ntotal
    annual cost is Rs.%.5f lakhs/year \nenergy
    received per year %ekWh/year \nwheeling charges
    Rs%f",rd,tac,ery,wc)
```
